

**FORM 'H'**  
**FORM FOR ISSUING FIRE SAFETY CERTIFICATE**  
**[Refer sub - rule (1) of rule 35]**  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No. F6/DFS/MS/WZ/2020/ 276

Dated: 14/8/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **Goodley Public School (Nursery)** Located at **BD Block, Shalimar Bagh, Delhi -110088** comprised of Ground + 02 Upper Floor owned/ occupied by **Goodley Public School (Nursery)** have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **23-07-2020** in the presence of Mrs. S. Singh (Director) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from **1.4.18/2020** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **14/08/2020** at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Principal, Goodley Public School (Nursery) Located at BD Block Shalimar Bagh, Delhi - 110088.
2. Directorate of Education Old Secretariat Delhi – 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

NJS

### INSPECTION REPORT

1. Name & address of the building: **Goodley Public School (Nursery) Located at BD Block Shalimar Bagh, New Delhi – 110088.**
2. Type of Occupancy : Educational ( Ground + 2 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : 3298-3398 dated 01-03-2011
6. Date of inspection : 23/07/2020
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer  
 from the building side : MRS. S. Singh (Director)
9. Year of Construction : 2004-5
10. Applicant's letter No. : Nil Dated -06/07/2020

No. of Students=613  
 No. of class rooms=23  
 Plot area=800sqm  
 Covered area=379sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided on Road</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5mtr	2x1.5m Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5cm	Provided	MR
	f. Door Size	100cm	110 Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	6 nos. ABC & CO <sub>2</sub> ISI marked	7 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	1 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm 1 1	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 5000Ltr	NA NA Provided NA Provided	NA NA NA NA MR

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings Nil as noted at serial numbers .....

The shortcomings communicated earlier have been completed

*[Signature]*  
 Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation ADO/WP

*[Signature]*  
 Signature of the Inspecting Officer  
 Name  
 Designation

*[Signature]* 30/7/2020

*[Signature]* Mention dimensions.

*[Signature]* 5/8/2020

*[Signature]*  
 Sir there is two stairs of width. Necessary correction is