GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2020/SZ/ 268 Dated:10./08../2020

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed Middle School, located at C-4,Vasant Vihar, New Delhi-110057 comprised of ground plus one upper floor own/occupied by Govt. of National Capital Territory of Delhi was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/987 Dated 10/07/2017.The premises was re-inspected by the officer concerned of this department on 25/07/2020 in the presence of Mrs. Achla Vohra (HOS)) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of DFS Rules 2010 and that the school building is fit for occupancy class "Educational Building" "B" with effect from the date of issue of this certificate for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 10/08/2020 at New Delhi by

(S. S. Tuli)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Co-Ed Middle School, C-4, Vasant Vihar, New Delhi-110057.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/6

INSPECTION REPORT				
1	Name & Address of the Building	Govt. Co-Ed Middle School, C-4Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Ground + 01 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/987 Dated 10/07/2017		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.03.2011		
7	Date of Inspection	25/07/2020		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Achla Vohra (HOS)		
10	Year of construction	2013-2014		
11	Applicant letter No.	Letter No. Nil dated 09/07/2020 (Email)		
S. No	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**As Per Old NOC**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to Building.**			
	• Road width	Required	6m	MR
	• Gate width	N/A	4.5m	NA
	• Width of internal road	N/A	N/A	NA
2	**Number, width, type & arrangement of exits**			
	a) Number of Staircase			
	➢ Upper floors	One	Two	MR
	➢ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➢ Upper floors	1.50m	1.50m & 1.35m	MR
	➢ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➢ Fire check door	N/A	N/A	N/A
	➢ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	01nos	MR
	e) Width of corridor	N/A	2.15m	N/A
	f) Door size	N/A	N/A	N/A
3	**Compartmentation.**			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	**Smoke Management system.**			
	• Basement	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NA	NA
5.	**Fire Extinguishers.**			
	• Total numbers	06No's	06No's	MR
	• Types	ABC / CO2	ABC -06	MR
	• ISI Marking	ISI marked	Provided	MR

N/7

6.	**First Aid Hose Reels.**			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A
7	**Automatic fire detection & alarming system**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants.**			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	**Yard Hydrants.**			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• **Terrace Level**			
	➢ Discharge of pump.	N/A	N/A	N/A
	➢ Head of pump.	N/A	N/A	N/A
	➢ Power supply.	N/A	N/A	N/A
	➢ Auto starting of pump.	N/A	N/A	N/A
14.	**Captive water storage for Fire Fighting.**			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	**Exit Signage.**	Required	Provided	MR

N/8

16.	**Provisions of Lifts.**			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	**Standby Power Supply**	N/A	N/A	N/A
18.	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	**Fire Control Room.**			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for the Protection of special Risk, if any.**			N/A

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule DFS Act-2007 and Rules 2010, the FSC issued vide letter No. F6/DFS/MS/School/2017/SZ/987 Dated 10/07/2017 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Mehmood
Designation: ADO (SJ)

DO (SD) 30/07

DCFO(SZ) 30/7

DO(SD) 31/07

ADO(SJ) – On EL leave upto 11/08/2020

ADO(MR) PT letter is put up for sign please

DELHI FIRE SERVICE
Date 30/7/20
Diary No. 1411
07/08/20
Chief Fire Officer