

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6 DFS/MS/School/2020/SZ/ 279

Dated: 14/08/2020

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Senior Secondary School No-2** located at **Molarband, New Delhi-110044** comprised of Ground floor plus one upper floor (Old Block) & Ground + three upper floor (New Block) was issued FSC by this department vide letter No. F6/DFS/MS/School/2017/SZ/1368 dated 15/09/2017. The said premises was re-inspected by officer concerned of this department on 28/07/2020 in presence of Mr. Krishan Kumar (Estate Manager) and observed that first floor of old building is demolished and now the school building (both old GF) & new building (G + 3 upper floor) have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/08/2020 at New Delhi by



(S. S Tuli)
**Dy. Chief Fire Officer
Delhi Fire Service**

9/c A

Copy to: -

1. The Principal, Govt. Girls Senior Secondary School No.-2, Molarband, New Delhi-110044.
2. The AE (E), Education (Maint) Sub Divn. M1-1, PWD, ITI Campus, Pusa, New Delhi-12

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

		New Delhi-110044 (ID-1925053)		
2	Type of Occupancy	Group-B, "Educational Building" (School)		
3	Building Comprised of	Old Bldg- Ground floor New Bldg- Ground plus three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/1368 Dated 15/09/2017		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	28/07/2020		
8	Name of the Inspecting Officers	Avtar Singh ADO		
9	Name & Designation of Officers from the building side	Mr. Krishan Kumar (Estate Manager)		
10	Year of construction	1998 & 2016		
11	Applicant letter No.	Outdoor Dairy No. 5735 Dated 10/06/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none">Road width	Required	6 mtr ✓	MR
	<ul style="list-style-type: none">Gate width	Required	4.5 mtr ✓	MR
	<ul style="list-style-type: none">Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none">➤ Upper floors➤ Basement floor	Old bldg- GF floor New bldg-02No's	Old bldg- GF floor New bldg-02No's	✓ MR
		-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none">➤ Upper floors➤ Basement floor	1.50 m	1.60 m ✓	MR
		-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	<ul style="list-style-type: none">➤ Fire check door➤ Pressurization	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	Required	New bldg- 2nos. ✓	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none">Fire check door.Sealing of electrical shafts.Fire rating of shaft door.Water curtainFire dampers.	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none">BasementUpper floors	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.	✓		
	<ul style="list-style-type: none">Total numbersTypesISI Marking	34 No 's	38 No's	MR
		ABC / Co2	ABC-32 & Co2-06	MR
		ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none">Total numbers on each floor.Length of hose-reel hose.	One (new bldg)	One (new bldg) ✓	MR
		30m	Provided	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA	-N/A-	-N/A-	-N/A-
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM (new bldg)	450 LPM (2 no's) (new bldg)	MR
	➤ Head of pump.	40 m	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	-N/A-	-N/A-
18.	Refuge Area			

-N/14-


19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Note: Earlier Old Building was consisted of Ground + 1 Upper floor, but 1st floor has been demolished and now consisting of Ground floor only.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F6/DFS/MS/School/2017/SZ/1368 Dated 15/09/2017 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.


29/07/2020


Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.RD)

DO (SD)





30/7

Defo(S2)



30/7

DO(SD)


30/7

ADO(MR)

F.T letter is put up for sign, please


08/08/2020