

**FORM 'H'**  
**FORM FOR ISSUING FIRE SAFETY CERTIFICATE**  
[Refer sub - rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No. F6/DFS/MS/WZ/2020/ EH/120

Dated: 10/08/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **McDonalds Family Restaurant by Connaught Plaza Restaurants Pvt. Ltd.** Located at **Shop in Park, Plot No. 2, Ground Floor, B Block, Community Centre, Shalimar Bagh, Delhi – 110034** was issued FSC vide Letter No. F6/DFS/MS/EH/WZ/2017/587 dated 25-04-2017. The Shop in Park Mall, Shalimar Bagh has already issued FSC vide letter no. F6/DFS/MS/WZ/2019/1907 dated 03/10/2019. The premises was re inspected by the officers concerned of this department on 15-07-2020 in the presence of **Sh. Manoj (Legal Adviser)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 10/08/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/08/2020 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-** Sh. Manoj (Legal Adviser), M/s. McDonalds Family Restaurant by Connaught Plaza Restaurants Pvt. Ltd. Located at Shop in Park, Plot No. 2, GF, B Block, Community Centre Shalimar Bagh, Delhi-110034.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: McDonalds Family Restaurant by Connaught Plaza Restaurants Pvt. Ltd., Shop in Park, Plot No. 2, Ground Floor, B Block, Community Centre, Shalimar Bagh, Delhi – 110034
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situating in Mall already issued NOC vide letter no. F6/DFS/MS/WZ/2019/1907 dated 03/10/2019)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/WZ/2017/587 dated 25-04-2017
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 15-07-2020
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Manoj (Legal Adviser)
9. Year of Construction : 2007
10. Applicant's letter No. : 2020061105339 dated 02/07/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	24m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	1x128cm, 1x180cm	Old Case
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA







14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	10, 000 litres	50, 000 Litres Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/WZ/2017/587 dated 25-04-2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Name *Uday Vir Singh*  
Designation *AO/WP*

Signature of the Inspecting Officer  
Name  
Designation

*AO/WP*  
*AO/WP*  
*AO/WP*  
*AO/WP - F-T*  
Sir FY letter is put up for signature