

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO.F6/DFS/MS/School/2020/SZ/ 286

Dated: 14/08/2020

FIRE SAFETY CERTIFICATE

Certified that the Vandana International Senior Secondary School located at Sector-10, Dwarka, New Delhi-110075, comprised of ground plus four upper floors owned/occupied by Ved Educational Welfare Society, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 25.07.2020 in the presence of Sh. V.P. Tondon (Chairman) and that the building/Premises is fit for occupancy class B "Educational building" with effect from 14/08/2020 for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 14/08/2020 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service


Copy to:

1. Director (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
2. Sh. V.P. Tondon (Chairman), Vandana International Senior Secondary School located at Sector-10, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

