GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2020/ 317 **Dated:** 01/09/2020

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School, Block D-3, Sector-16, Rohini, Delhi-89**, comprised of **Two blocks- Ground + One Upper floor** owned/occupied by **MCD Primary School** was issued fire safety certificate by this department vide letter no.**F6/DFS/MS/School/2017/794 dated 02.06.2017** The premises was re-inspected by the officer concerned of this department on **19.08.2020** in the presence of **Smt. Bhawna (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **class "B"Educational Buildings** with effect from 01/09/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 01/09/2020 at New Delhi by

28/8/2020

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01125156707

01 C
MS

Copy to:

1. The Principal, MCD Primary School, Block D-3, Sector-16, Rohini, Delhi-89
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : MCD Primary School, Block D-3, Sector-16, Rohini, Delhi-89
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2017/794 dated 02.06.2017
5. Fire Safety directives letter No : Direction of Education dated 01/03/2011
6. Date of inspection : 19.08.2020
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers

   From the building side : Smt. Bhawna (Principal)
9. Year of Construction : 2005
10. Applicant's letter No. : nil dated 31.07.2020, O.D. No.6515 dated 04.08.2020

Plot Area4150-Sqm Covered Area: 2875 Sqm No. of Class Room:33

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE requirement	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	Accessible	6.0 mtr	MR
	• Gate width	Accessible	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	A-Blk-01 B-Bkl-02	A-Blk-01 B-Bkl-02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 mtr	1.50 mtr each	M.R
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	01	01	01
	f. Door Size	NA	NA	NA
		1 mtr	1.5 mtr	M/R
3.	**Compartmentation**			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	**Fire Extinguishers**			
	• Total numbers	10 No's	11 No's	MR
	• Types	ABC/CO2	ABC/CO2	MR

6.	**First-Aid Hose Reels**			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	**Automatic fire detection and alarming system**			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel		NA	NA
	• Location of Repeater Panel		NA	NA
	• Alternate source of power		NA	NA
	• Hooters' Location		NA	NA
8.	**MOEFA**	NA	NA	NA
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	**Yard Hydrants**			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	NA	NA	MR
	➢ Head of the pump	NA	NA	MR
	➢ Power Supply	NA	NA	MR
	➢ Auto Starting of pump	NA	NA	NA
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	**Exit Signage.**	NA	NA	NA
16.	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

M-H

	Standby power supply	NA	NA	NA
18.	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2017/794 dated 02.06.2017 **is** recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

21/8/xx

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Correct the DFA

Anilash 20/8/xx

A.K. MALIK

(R)

Corrected DFA is put up for kind perusal and approval please.

21/8/xx

DO (NW)

Anilash 21/8/xx

A.K. MALIK

Dy CFO (W2)

If this is put up for