FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/WZ/2020/ 328 **Dated:** 08 **/09/2020**

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Bal Vidyalaya** Located at **Anand vas (Lok Vihar)(School ID-1411001), Delhi-110034,**comprised of **03 Block (Ground + 1 Upper Floor)** owned and occupied by **Sarvodaya Bal Vidyalaya** issued FSC vide Letter No.: F6/DFS/MS/SCHOOL/2017/514 Dated-05/04/2017. The premises was re inspected by the officer concerned of this department on 31/08/2020 in the presence of Mr. S.K. Singh (HOS) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011/ NBC Part IV and that the premises is fit for occupancy class "Educational" Group B with effect from 08/09/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/09/2020... at New Delhi by.

4/9/2020

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, Sarvodaya Bal Vidyalaya, Anand Vas (Lok Vihar) (School ID-1411001), Delhi-110034.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the exits must be kept open & free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/S^

INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Bal Vidyalaya** Located at **Anand vas (Lok Vihar)(School ID-1411001), Delhi-110034.**
2. Type of Occupancy : Educational 03 Block (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/SCHOOL/2017/514 Dated-05/04/2017
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 31/08/2020
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer from the building side :Mr. S. K. Singh (HOS)
9. Year of Construction : 1976

No. of Students=2287
No. of class rooms=46
Plot area=8000sq yard
Covered area=4000sq yard

10. Applicant's letter No. : SBV/AV/2020/570 dated .20/08/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	8m Provided	MR
	• Gate width	Accessible	5m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	**BL-1&2=02 BL-3=01**	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1x150cm	**BL-1**=2x150cm(**including railing**) **BL- 2**=1x160,1x150cm(**including railing**) **BL-3**=1x150cm(**including railing**)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	155cmProvided	MR
	f. Door Size	1 mtr	115cmProvided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	• Total numbers	18nos.	18 Provided	MR
	• Types	ABC & CO_2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Staring/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power supply	NA	NA	NA
	➢ Auto starting of pump	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➢ Draw off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	NA	NA	NA
	➢ Fireman's Grounding Switch	NA	NA	NA
	➢ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➢ Total area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire control room			
	➢ Detector system panel	NA	NA	NA
	➢ Flow Switch Panel	NA	NA	NA
	➢ PA System Panel	NA	NA	NA
	➢ Battery backup	NA	NA	NA
	➢ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2017/514 Dated-05/04/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

3/8/2020

Signature of the Inspecting Officer
Name Udai Vir Singh
Designation ADO/WP

Signature of the Inspecting Officer
Name
Designation

DO/W

7/9/2020

Dy. CFO (W2)

7/9/2020

ADO/WP - FT