

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2020/SZ/ 368

Dated: 23/9/2020

FIRE SAFETY CERTIFICATE

Certified that **Good Samaritan Senior Secondary School**, located at **Sector-8, Jasola, New Delhi-110025** comprised of Ground + three upper floors was granted fire safety certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/1071 dated 26/04/2017. The building /premises was re-inspected by officer concerned by this department on 01/09/2020 in the presence of Mr. Chakarvarti (Maintenance Incharge) of the school and found that said school building have complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service, 2010 and that the school building is fit for occupancy class "**Education Building**" **Group-B**, as above with effect from 23/9/2020.. for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/9/2020 at New Delhi by



(S.S. Tuli)  
Dy. Chief Fire Officer  
Delhi Fire Service



Copy to: -

1. The founder Manager, Good Samaritan Senior Secondary School, located at Sector-8, Jasola, New Delhi-110025
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1	Name & Address of the Building	Good Samaritan Senior Secondary School, Sector-8, Jasola, New Delhi-110025		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/1071 dated 26/04/2017		
6	Fire Safety Directives Letter No	F6/DFS/MS/2002/517 dated 26/03/2002		
7	Date of Inspection	01/09/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Chakarvarti (Maintenance Incharge)		
10	Year of construction	2002		
11	Applicant letter No.	Outdoor diary no 1243 dated 17/08/2020		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Dt. 17/11/2005 Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	Accessible	9 m ✓	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	5 m	5 m ✓	MR
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	N/A	6 m Provided	NA
<b>2</b>	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	4 nos	4 nos ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floor	1.5 m each	1.5 m each ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	04 nos ✓	MR
	<b>e) Width of corridor</b>	1.5 m	Provided	MR
	<b>f) Door size</b>	N/A	N/A	N/A
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire rating of shaft door.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire dampers.</li> </ul>	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	30 ACPH	NA	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 ACPH	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	30 No's	38 No's ✓	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC / CO <sub>2</sub>	ABC-30 / CO <sub>2</sub> -08	MR
	<ul style="list-style-type: none"> <li>ISI Marking</li> </ul>	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> </ul>	Hose Reels	4 nos ✓	MR
	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>		30 m	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>		5 mm ✓	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A

9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	150 mm ✓	MR
		Required	4 nos ✓	MR
		Required	4 nos ✓	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	Provided	N/A
		N/A	Provided	N/A
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby pump head.</li> <li>Auto Starting/Manual Stopping.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>			
		1620 LPM	1620 LPM ✓	MR
		54 m	54 m ✓	MR
		One	One	MR
		225 LPM	225 LPM ✓	MR
		54 m	54 m ✓	MR
		1620 LPM	1620 LPM ✓	MR
		54 m	54 m ✓	MR
		Required	Provided	MR
		450 LPM	450 LPM ✓	MR
		40 m	40 m ✓	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	50,000 ltrs	50,000 ltrs ✓	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided ✓	MR
		10,000 ltrs	10,000 ltrs	MR
15.	<b>Exit Signage.</b>	N/A	Provided	N/A
16.	<b>Provisions of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided ✓	N/A
17.	<b>Standby Power Supply</b>	N/A	Provided	N/A
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel.</li> <li>Flow Switch Panel.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

- N/A -

	<ul style="list-style-type: none"><li>Battery backup</li><li>Building floor plan</li></ul>	N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	01 ABC & 01 CO2 type fire extinguisher found provided near electrical panel	N/A

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No F6/DFS/MS/School/2017/SZ/1071 dated 26/04/2017 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

*Avtar Singh*  
02/09/2020

Signature of the Inspecting Officer

Name: Avtar Singh

Designation: ADO (MR)

~~DO (SD)~~

*DO (SD)*  
07/09

~~Defo (S2)~~

*Defo (S2)*  
5/9/2020

~~DO (SD)~~

*DO (SD)*  
18/09

~~ADO (MR)~~

F.T. Letter is put for signature please.

*Prakash*  
21/9/2020

~~DO (SD)~~

*DO (SD)*  
22/9

M's call

