

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6 DFS/MS/School/2020/SZ/ 377

Dated: 29/09/2020

FIRE SAFETY CERTIFICATE

Certified that the Modern New Delhi Public School located at L-1/133, Near Asthal Mandir, Sangam Vihar, New Delhi-110062 comprised of basement, ground plus three upper floors was granted FSC by this department vide letter No. F.6/DFS/MS/School/2017/SZ/1231 dated 18/08/2017. The said premises was re-inspected by officer concerned of this department on 21/09/2020 in presence of Mr. Pawan Garg (Owner) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education circular No.F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/09/2020 at New Delhi by


28/09

(S. S. Tuli)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, Modern New Delhi Public School, L-1/133, Near Asthal Mandir, Sangam Vihar, New Delhi-110062
2. The Directorate of Education, Govt. of NCT of Delhi Old Secretariat, New Delhi 110002.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

218

INSPECTION REPORT

1	Name & Address of the Building	Modern New Delhi Public School, L-1/133, Near Asthal Mandir, Sangam Vihar, New Delhi-110062		
2	Type of Occupancy	Educational Building (School)		
3	Building Comprised of	Small Basement, Ground Plus Three Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/1231 dated 18/08/2017		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	21/09/2020		
8	Name of the Inspecting Officers	D.B. Mukherjee, DO (SD)		
9	Name & Designation of Officers from the building side	Mr. Pawan Garg (Owner)		
10	Year of construction	2005-2006		
11	Applicant letter No.	Letter No. MNDPS/Fire Certificate/2020 Dated 04/09/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6m	MR ✓
	• Gate width	Required	4.5m	MR ✓
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	Required	Two	MR ✓
	➤ Basement floor	Required	One	MR ✓
	b) Width of Staircase			
	➤ Upper floors.	Required	1.5m & 1.07m to 1.20m	MR ✓
	➤ Basement floor	-N/A-	1.50m	-N/A- ✓
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A- ✓
	➤ Pressurization	-N/A-	-N/A-	-N/A- ✓
	d) No. of continuous staircase to terrace	Required	Two	MR ✓
	e) Width of corridor	-N/A-	-N/A-	-N/A- ✓
	f) Door size	1 mtr	Provided	MR ✓
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A- ✓
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A- ✓
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A- ✓
	• Water curtain	-N/A-	-N/A-	-N/A- ✓
	• Fire dampers.	-N/A-	-N/A-	-N/A- ✓
4.	Smoke Management system.			
	• Basement	Required	Exhaust Fan	MR ✓
	• Upper floors	-N/A-	-N/A-	-N/A- ✓
5.	Fire Extinguishers.			
	• Total numbers	22No 's	22No's	MR ✓
	• Types	ABC / Co2	ABC-22	MR ✓
	• ISI Marking	ISI Marked	Provided	MR ✓
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Two	Provided	MR ✓
	• Length of hose-reel hose.	30m	Provided	MR ✓
	• Nozzle Diameter	5mm	Provided	MR ✓


2/10

19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	ABC type fire extinguisher provided near electric panel	MR

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under Director of Education circular, FSC issued vide letter No F.6/DFS/MS/School/2017/SZ/1231 dated 18/08/2017 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: D.B. Mukherjee
 Designation: DO (SD)

Dy.CFO (SZ)

F.T. please.



Signature
25/09

DO (SD)

F.T. letter is put up for signat.

Signature
28/09/2020

Dy CFO (SZ)

Signature
28/09

MS call