

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No:-F6/DFS/MS/WZ/School/2020 / 406

Dated: 07/10/2020

FIRE SAFETY CERTIFICATE

Certified that the **Government Girls Senior Secondary School** located at **A – Block, Kirti Nagar, New Delhi – 110015** comprised of Total- 4 Blocks, Ground + 01 Upper Floor was issued FSC vide Letter No. **F6/DFS/MS/School/2017/1440** dated **29/09/2017**. The premises was re inspected by the officers concerned of this department on **28-09-2020** in the presence of Miss. Rekha Bhatla (Vice Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class “Educational” Group B with effect from 07/10/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/10/2020.... at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 11005
2. Miss. Rekha Bhatla (Vice Principal) GGSSS, A Block, Kirti Nagar, New Delhi – 110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Government Girls Senior Secondary School, A Block, Kirti Nagar, New Delhi.**
2. Type of Occupancy : Educational Total- 4 Blocks Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC no.:F6/DFS/MS/School/2017/1440 dated 29/09/17
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 28/09/2020
7. Name of the Inspecting Officer : Udai vir ADO (WP)
8. Name and designation of Officer
from the building side : Miss. Rekha Bhatla (Vice Principal)
9. Year of Construction : 2013
10. Applicant's email letter no. : nil dated 17/09/2020

Total Area = 6451.13 m ²
Covered Area = 2784.17 m ²
No. of class rooms = 22
Total no. of Students = 931

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	7m Provided	MR
	• Gate width	Accessible	600cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Block-1&4=1 Block-2=3 Block-3=2	BL-1&4=1 Provided BL-2=3 Provided BL-3=2 Provided BL-4=1 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	BL-1=1.52cm BL-2=3X 1.52cm BL-3=2x1.52 cm BL-4=1x152cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 in each block	Provided	MR
	e. Width Of Corridor	1.5 m	172 cm	MR
	f. Door Size	2X1 mtr	107cm Provided	MR

14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No F6/DFS/MS/School/2017/1440 dated 29/09/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

10/28/2020
Signature of the Inspecting Officer
Name Udai Vir Singh
Designation ADO (WP)

Date 18/9/2020
By ADO (W2)
29/9/2020
ADCP/1- FT
Sir AF letter is put up for
Sign ple