

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2020/SZ/ 385

Dated: 30/9/2020

FIRE SAFETY CERTIFICATE

Certified that the Holy Child Auxilium School located at R. K. Puram, Sec-XII, New Delhi-110022, comprised of three blocks-School block – G +2 & Auditorium Block- ground plus two upper floors, Residential block –basement, ground plus two upper floors (FSC apply only for school building) was inspected by the officer concerned of this department on 23/09/2020 in presence of Sr. Leela (Principal) of the school and found that the school building have complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class “Educational Building, Group-B” as above with effect from 30/9/2020 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010..

Issued on 30/9/2020 at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Copy to: -

1. The Principal, Holy Child Auxilium School, R. K. Puram, Sec-XII, New Delhi-110022.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form ‘J’ [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Holy Child Auxilium School, R. K. Puram, Sec-XII, New Delhi-110022		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	School has three blocks 1.School block-G +2 upper floors 2) Auditorium Block -ground plus two upper floors, 3) Residential block- basement, ground plus two upper floors (FSC applied only for school building)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23/09/2020		
8	Name of the Inspecting Officers	D.B. Mukherjee, DO (SD)		
9	Name & Designation of Officers from the building side	Sr. Leela (Principal)		
10	Year of construction	1980	Recognized letter submitted for construction proof at C-21	
11	Applicant letter No.	Letter No. Nil Dt.27/07/2020 (Email)		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	6 m	9 m	MR
	2. Gate width	-NA-	-NA-	-NA-
	3. Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	1. Upper floors	Two	Two	MR
	2. Basement floor	-NA-	-NA-	-NA-
	b. Width of Staircase			
	1. Upper floors	1.50 m	1.50m each	MR
	2. Basement floor	-NA-	-NA-	-NA-
	c. Protection of exits			
	1. Fire check door	-NA-	-NA-	-NA-
	2. Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	01no	Provided	MR
	e. Width of corridor	1.50m	2.67m	MR
	f. Door size	Required	1.10m	MR
3	Compartmentation.			
	1. Fire check door.	-NA-	-NA-	-NA-
	2. Sealing of electrical shafts.	-NA-	-NA-	-NA-
	3. Fire rating of shaft door.	-NA-	-NA-	-NA-
	4. Water curtain	-NA-	-NA-	-NA-
	5. Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	1. Basement	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	1. Total numbers	22 No's	22No's	MR
	2. Types	ABC /Co2	ABC, Co2	MR
	3. ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	Required	02 nos. Provided at each floor	MR
	2. Length of hose-reel hose.	30m	Provided	MR
	3. Nozzle Diameter	5mm	Provided	MR

7	Automatic Fire Detection and Alarming System.			
	1. Type of detectors	-NA-	-NA-	-NA-
	2. Location of Main Panel	-NA-	-NA-	-NA-
	3. Location of Repeater Panel	-NA-	-NA-	-NA-
	4. Alternate source of power	-NA-	-NA-	-NA-
	5. Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA / SIREN	-NA-	-NA-	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1. Basement.	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
	3. Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	-NA-	-NA-	-NA-
	2. Number of Hydrant per floor	-NA-	-NA-	-NA-
	3. Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	1. Total number of hydrants.	-NA-	-NA-	-NA-
	2. Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450LPM	900LPM	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 liter	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	-NA-	-NA-	-NA-
	2. Pressurization of lift lobby.	-NA-	-NA-	-NA-
	3. Communication in lift car.	-NA-	-NA-	-NA-
	4. Fireman's switch.	-NA-	-NA-	-NA-
	5. Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	1. Total area	-NA-	-NA-	-NA-
	2. Location	-NA-	-NA-	-NA-

N/10

19.	Fire Control Room.			
	1. Detector System Panel.	-NA-	-NA-	-NA-
	2. Flow Switch Panel.	-NA-	-NA-	-NA-
	3. PA system Panel.	-NA-	-NA-	-NA-
	4. Battery backup	-NA-	-NA-	-NA-
	5. Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.</p> <p>The school management submitted Undertaking at C-20, Recognized letter for construction proof at C-21. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
				<p><i>[Signature]</i> 24/09/2020 Signature of the Inspecting Officer Name: D. B. Mukherjee Designation: DO (SD)</p>

Dy. CFO (SZ)

[Signature]
25/09

[Signature]

[Signature]

[Signature]
28/9

[Signature]
28/9/2020

SI Plc

[Signature]

F.T. letter is put up for sign. hd.

[Signature]
29/9/20

[Signature]
28/09/2020

[Signature]

