GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: director.dlfire@nic.in, Tel:- 011-23414000

No..F6/ DFS/ MS/SZ/ 2020/ 396 Dated: 05/10/2020

FIRE SAFETY CERTIFICATE

Certified that, **Jagan Nath Gupta Memorial Educational Society,** Located at Sec-B-OCF, Pocket-9,Vasant Kunj, New Delhi, havingTwo Blocks both comprised of Basement, Ground + 03 Upper Floors was granted **NOC** by this department vide letter No. F6/MS/DFS/2004/2866 Dated-01/12/2004. The premises was re-inspected by the officer concerned of this department on 24/09/2020 in the presence of Mr. Amit Kamra, Administrative Officer and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational** with effect from-05/10/2020----for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 05/10/2020 at New Delhi by.

(Atul Garg)
DIRECTOR

Copy to: -

1. Dr. Amit Gupta, Jagan Nath Gupta Memorial Educational Society, Sec-B-OCF, Pocket- 9,Vasant Kunj, New Delhi-110019.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on **www.dfs.delhigovt.nic.in**

INSPECTION REPORT

1. Name & address of the building :Jagan Nath Gupta Memorial Educational Society, Sec-B-OCF, Pocket- 9,Vasant Kunj, New Delhi
2. Type of Occupancy : Educational
3. Type of Case : New/Addition
4. Details of previous NOC : F6/MS/DFS/2004/2866 Dated-01/12/2004
5. Fire Safety directives letter No : No.F6/DFS/MS/BP/2014/338 Dated: 18/12/2014
6. Date of inspection : 25/09/2020
7. Name of the Inspecting Officers : D.B. Mukherjee, DO(SD)
8. Name and designation of officers from the building side : Mr. Amit Kamra (Administrative Officer)
9. Year of Construction :2003 & 2014
10. Applicant's letter No. : Through email dated: 22/09/2020

(Building is in two blocks A block is comprised of Basement, Ground + Three upper Floors & B block is comprised of Basement, Ground + Three Upper floor.)

Sl. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remark MR/NMR
1	**Access to building**			
	• Road width	9 m	Provided	MR
	• Gate width	5 m	02 Nos 5m & 4.85 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
2	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	Upper Floors	02	A block 02 Nos B block 02 Nos	MR
	Basements	02	A block- 02 No. & Ramps 02 B block- o2 No.	MR
	b. Width of staircases			
	Upper Floors	1.50 m	A block - 1.12 mtr,1.51 mtr B block – 1.52m, 1.24 mtr	MR
	Basement	1.50m	A-Block-1.52m,1.17m Ramp 3mtr & 3.05mtr B Block-1.52m & 1.24 m	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	04	MR
	e. Width of Corridor	1.5m	Provided	MR

	f. Door Size	Required	Provided	MR
3	**Compartmentation.**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	**Smoke Management System.**			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	N/A	N/A
5	**Fire Extinguishers**			
	• Total numbers	Required	18 nos	MR
	• Types	ABC,Co_2	Provided	MR
	• IS marking	Required	Provided	MR
6	**First-Aid Hose Reels.**			
	• Total numbers on each floor	01	Provided in both blocks	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	**Automatic fire detection and alarming system.**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	**MOEFA**	N/A	N/A	N/A
9	**Public Address System.**	N/A	N/A	N/A
10	**Automatic Sprinkler System**			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants**			
	Size of riser/down-comer	Not Required	Provided	MR
	Number of hydrants per floor	01	Provided	MR

	Hose Box	01	Provided	MR
12	**Yard Hydrants.**			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	**Pumping Arrangements**			
	• Ground Level			
	Discharge of main Pump	NR	Provided 1620 LPM	MR
	Head of Main pump	60 mtr	Provided	MR
	Number of main pumps	01no	Provided	MR
	Jockey Pump out put	180 LPM	Provided	MR
	Jockey pump head	60 mtr	Provided	MR
	Standby Pump out put	N/A	N/A	N/A
	Standby Pump Head	N/A	N/A	N/A
	Auto Starting/ Manual stopping	Required	Provided	MR
	Pump House Access	N/A	N/A	N/A
	• Terrace level			
	Discharge of pump	900 LPM	Provided	MR
	Head of the pump	40 mtr	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	50,000ltr	Provided	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000Ltr	20,000Ltr	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/15

17	**Standby power supply**	Required	Provided D G Set	MR
18	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/MS/DFS/2004/2866 Dated-01/12/2004 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended. Accordingly DFA is put up for approval pl.

What about earlier shortcomings.

25/09/2020

Signature of the Inspecting Officer
Name (D.B.Mukherjee)
Designation :- Divisional Officer(SD)

Dy. CFO (SZ)

25/09

DFO (SD) Sir the shortcomings were based on the guidelines issued vide no. F6/DFS/MS/BP/2014/338 dt. 18/12/14. However in reply of Dr. Amit Gupta has been received via e-mail dt. 22/09/2020 in which they have asked to relax the shortcomings as per NBC - Part IV - 2005 which may be accepted The actual requirement is reflected in my Inspetion note. Submitted pl.

25/09/2020

DELHI FIRE SERVICE Date 30/9/20 880 CIVIL WING OFFICE

DH CFO (SZ)

28/09

CI Plc

DELHI FIRE SERVICE Date 28/9/20