

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/2020/SZ/ 407

Dated: 07/10/2020

FIRE SAFETY CERTIFICATE

Certified that M/s Multi Level, Car Parking located at Near Terminal-3, IGI Airport, New Delhi-37, comprised of ground plus six upper floors(Sixth floor for office purpose some portion) Owned/occupied by Delhi International Airport Limited was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2017/SZ/1499 dated 17/10/2017. The premise was re-inspected by the officer concerned of this department on 12/09/2020 in the presence of Mr. Anil Sharma (Fire Officer) and found that the said parking building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-H "Storage" (Car Parking) with effect from 07/10/2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/10/2020 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Sh. Hrishikesan, General Manager, Airport Rescue and Fire Fighting, Delhi International Airport (P) Ltd. NewDelhi-37
2. **Operational Head** Multi Level, Car Parking located at Near Terminal-3, IGI Airport, New Delhi-37.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Multi Level, Car Parking at Terminal-3, IGI Airport, New Delhi-37.		
2	Type of Occupancy	Class-H "Storage"		
3	Building Comprised of	Ground + 06 upper floors (Office at 6 th floor).		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2017/SZ/1499 dated 17/10/2017		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2009/1247 dated 08/05/2009		
7	Date of Inspection	12/09/2020		
8	Name of the Inspecting Officers	DO S.K. Dua & ADO Bhupender Prakash		
9	Name & Designation of Officers from the building side	Mr. Anil Sharma (Fire Officer)		
10	Year of construction	2010		
11	Applicant letter No.	Outdoor diary No. 6018 dated 22/06/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements/ Existing fire protection system	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m	9 m	MR
		6 m	6 m	MR
		6 m	6 m	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	5nos.+ 4ramp	5nos.+ 4ramp	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5(each)+4.5(each)	1.5(each)+4.5(each)	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	5 nos.	5 nos.	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	70 nos.	90 nos.	MR
	• Types	ABC/CO ₂ / W.CO ₂	ABC/CO ₂ / W.CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	5 nos.	5 nos.	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Smoke & Heat	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	FCR	Fire Control Room	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	On Each floor	Provided	MR

8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	150 mm	150 mm	MR
		5 nos.	5 nos.	MR
		5 nos.	5 nos.	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	11 nos.	11 nos.	MR
		11 nos.	11 nos.	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	2280 LPM(Two)	Provided	MR
		80 m(Two)	Provided	MR
		02 nos.	02 nos.	MR
		180 LPM(Two)	180 LPM(Two)	MR
		80 m	80 m	MR
		2280 LPM	2280 LPM	MR
		80 m	80 m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	900 LPM	900 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	100000 Ltrs	100000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Lts	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

17.	Standby Power Supply	Required	380KVA(Two)	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	Required	Provided	MR
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required for transformers, LT & HT panels	Provided (CO ₂ local application)	MR

The Fire protection systems provided in the building were checked/ operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2017/SZ/1499 dated 17/10/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Brakash
28/9/2020

S.K. Dua
14/09/20

Signature of the Inspecting Officer
Name: S.K. Dua
Designation : DO (SD)

Renewal: M/s Multi Level, Car Parking at Terminal-3, IGI Airport, New Delhi-37.

DCFO (SZ)



CFO

Guid 15/9 Why ADO has not signed.

16/9



DFS (SZ)
Guid 18/9

DO (SD)

14/9/20



ADO (RSP) As directed, I have signed the inspection report.

Brakash