

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2020/ 409

Dated: 07/10/2020

FIRE SAFETY CERTIFICATE

Certified that the **S. D. M. C. Primary School**, Located at **Shivaji Enclave, New delhi-110027**, comprised of **Ground + 01 Upper Floors** only was issued FSC vide Letter No. **F6/DFS/MS/School/2017/411 dated 17/03/2017**. The premises was re inspected by the officer concerned of this department on **29/09/2020** in the presence of **Ms. Neelam Pahwa (Principal)** All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE 3298-3398 dated 1-3-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 07/10/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/10/2020 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Directorate of Education Old Secretariat Delhi – 110054
2. The Principal, S. D. M. C. Primary School, Located at Shivaji Enclave, New delhi-110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **S. D .M. C. Primary. School (ID-1556072)**
 Located at **Shivaji Enclave, New Delhi-110027**

2. Type of Occupancy : Educational (Ground +One Upper Floor)

3. Type of Case : Renewal

4. Details of previous NOC :F6/DFS/MS/School/2017/411 dated 17/03/2017

5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11

6. Date of inspection : 29/09/2020

7. Name of the Inspecting Officer : ADO (WP)

8. Name and designation of Officer

from the building side : **Miss. Neelam Pahwa (Principal)**

9. Year of Construction : 2015

10. Applicant's letter No. : Nil dated 11/09/2020

Area of School -4700m ²
Covered Area – 1400m ²
Class Rooms –15
Total Students – 516

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	8m Provided	MR
	• Gate width	Accessible	366cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	3x150cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	2m Provided	MR
	f. Door Size	1 m	110cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA


5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 nos. ABC & CO ₂ ISI marked	05 Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 		NR	NR
			NR	MR
			NR	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
8.	MOEFA		NA	NA
9.	Public Address System		NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 		NA	NA
			NA	NA
			NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 		NA	NA
			NA	NA
			NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		NA	NA
			NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 		NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 		NA	NA
			NA	NA
			NA	NA
			NA	NA
			NA	NA
15	Exit Signage	NA	NA	NA


Jh





16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. **F6/DFS/MS/School/2017/411 dated 17/03/2017** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer
Name: Sh. Udai Vir Singh
Designation: ADO (WP)


Signature of the Inspecting Officer
Name
Designation

 
 
AAO/pe R. FT
Sir AP letter is part of for h/p file
the 12/2020