

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2020 / 407

Dated: 7 / 10 / 2020

FIRE SAFETY CERTIFICATE

Certified that the **Shaheed Udham Singh Primary Public School** located at **A-Block, Shastri Nagar, Delhi – 110052** in a building comprised of Ground + 01 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/2017/School/WZ/1645 dated 16/11/2017**. The premises was re inspected by the officer concerned of this department on **25/09/2020** in the presence of **Sh. Gordhan Das Sharma(Chairman)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 07/10/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/10/2020 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054
2. The Principal, Shaheed Udham Singh Primary Public School, Located at A-Block, Shastri Nagar, Delhi-110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Shaheed Udham Singh Primary Public School located at A-Block, Shastri Nagar, Delhi – 110052.**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2017/School/1645 Dated 16/11/17
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 25/09/2020
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Gordhan Das Sharma (Chairman)
9. Year of Construction : 2008-09
10. Applicant's email letter no. : Nil Dated 20/09/2020

No. of Students=450
No. of class rooms=13
Plot area=4840 Sqy
Covered area=848 Sqy

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 410cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 2 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 2x1.5m NA 	<ul style="list-style-type: none"> 123,130cm NA 	<ul style="list-style-type: none"> MR(Old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	161cm Provided	MR
	f. Door Size	1m	1m Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA

5.	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	8 nos. ABC & CO ₂ ISI marked	10 Provided Provided Provided	MR MR MR	
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30m 5mm	Provided Provided Provided	NA NA NA	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters’ Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA	
8.	MOEFA				
9.	Public Address System				
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA	
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	Provided Provided	NA NA	
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA 450lpm Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA NA NA NA	
14.	Captive water Storage for firefighting:				
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA NA NA NA NA	NA NA NA NA 5000 ltrs Provided	NA NA NA NA NA	
15	Exit Signage	Required	Provided	MR	

[Handwritten Signature]

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2017/School/WZ/1645 dated 16/11/2017** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name: Sh. Udai Vir Singh
 Designation: ADO/WP

Signature of the Inspecting Officer
 Name: Sh. P.V. Rathi
 Designation: ADO

DO/CO *29/11/2020*

Dr. G.P. WZ,

ADO/WP - FT

Dr. G.P.

Dr. G.P. letter is kept for by Mr

15/10/2020