

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2020/SZ/388

Dated: 01/10/2020

FIRE SAFETY CERTIFICATE

Certified that the **Holy Innocents Public School**, Plot No.-PS/09, C-Block, Vikaspuri, New Delhi-110018, comprised of basement, ground floor plus three upper floors, having total 39 rooms (including class rooms, office, Labs (Physics, Chemistry, Biology), Comp. Room & Store etc.), owned/occupied by Holy Innocents Public School was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/School/2016/SZ/1839 dated 26.12.2016. The School building was re-inspected by the officer concerned of this department on 16.09.2020 in the presence of WG. Cdr. S.K. Nangia (Manager) and found that the Holy Innocents Public School have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....01/10/2020..... at New Delhi.

[Signature]
29/09

(S.S. TULI)
Dy. CHIEF FIRE OFFICER
SOUTH ZONE

[Signature]
28/09/2020

Copy to:-

1. The Manager,
Holy Innocents Public School, Plot No.-PS/09,
C-Block, Vikaspuri, New Delhi-110018
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. In case usage of basement is other than storage then FSC will be null and void.

INSPECTION REPORT

1. Name & address of the building : Holy Innocents Public School, Plot No.-PS/09, C-Block, Vikaspuri, New Delhi-110018.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2016/SZ/1839 dated 26.12.2016
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2000/1241 dated 18.07.2000 & F.6/DFS/MS/BP/2002/2288 dated 28.11.2002
6. Date of inspection : 16.09.2020
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : WG. Cdr. S.K. Nangia (Manager)
9. Year of Construction : 2000-2002
10. Applicant's letter No. : HIPS/FS/MS/2020 dated 01.09.2020 along with Form "J" & "K"

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	12 mtrs 5.15 & 3.9 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No's	02 No's	MR
		02 No's	02 No's	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms	150 & 153 cms	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	150 cms	150 & 150 cms	MR
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	Required	One	MR
	f. Door Size	150 cms	160 cms	MR
		100 cms	112 & 114 cms (06 rooms single door)	MR, students are less than 45 in each classroom with single door
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required	Exhaust fans are provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	24 no.'s	Provided	MR
		ABC/CO ₂ /WCO ₂ type	Provided	MR
		ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 no.'s	Provided	MR
		30 mtrs	Provided	MR
		5 mm	Provided	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	100 mm	N/A
		N/A	Two	N/A
		N/A	Two	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM & 180 LPM	450 LPM & 180 LPM provided	MR
		30 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		8000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			No Lift
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

A/27

19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings communicated by this department vide letter no. F.6/DFS/MS/School/2020/SZ/146 dated 02.03.2020 have been complied.

In view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2016/SZ/1839 dated 26.12.2016 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per form "J" all classes having double doors except few rooms where students entry level is less than 45. The basement is being used only for storage purpose as approved in sanctioned plans

Sandeep
21/09/2020

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

D.O. (South West)

300/DO/SW
21/9/2020

[Signature]
21/8

DCO(S2)
[Signature]
22/9

DO(SW)
[Signature]
23/8

ADD (S/O)
FT. letter is put up for signature please
Sandeep
28/09/2020

