

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2020/ 413

Dated: 08 / 10 /2020

FIRE SAFETY CERTIFICATE

Certified that the M/S Sirifort institute of Management Studies, Rohini Sector -25, Delhi, comprised of Ground + 4 upper floors owned/ occupied by the M/S Sirifort institute The building was inspected by the officer concerned of this department in the presence of Dr. Mahabir Yadav (Director General) on dated 08.08.2020 and found that the building have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy class **Group B” Educational Building’** with effect from 08/10/2020....for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 08/10/2020.... at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi – 54.
2. Director General, Dr. Mahabir Yadav, M/S Sirifort institute of Management Studies, Rohini Sector -25, Delhi.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form ‘J’ [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
- 7 The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

Earlier (G+3)

Present (G+4)

1. Name & address of the building : Sirifort institute of Management Studies, Rohini Sector -25, Delhi
2. Type of Occupancy : Class-B (Education)
3. Type of Case : New Case
4. Details of Previous NOC :
5. Fire Safety directives letter No : F6.DFS/MS/BP/2015/117 dated 28.04.2015
6. Date of inspection : 25.09.2020
7. Name of Inspecting Officer : ADO-A.K. Sharma & DO A.K. Malik (NWD)
8. Name and designation of officers
From the building side : Sh. Priti Dagar (Owner)
9. Year of Construction : 2005
10. Applicant's letter No. : Online email date 23.07.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12m 4.5m 6.0m	12m 4.5m Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 -NA-	02 -NA-	MR -NA-
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5mtr -NA-	1.7 & 1.5 mtr -NA-	MR -NA-
	f. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircases to terrace	1 No.	2 No.	MR.
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0 mtr	1.20 mtr	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required -NA- -NA- -NA-	Provided Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	-NA- 12 a/c per hour	-NA- Natural ventilation	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 No's ABC/W. CO ₂ /CO ₂ ISI marked	12No's 10/2 No's Yes	MR MR MR
6.	First-Aid Hose Reels			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- All floors	-NA- -NA- -NA- -NA- -NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm One One	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	-NA- -NA- -NA- -NA- -NA- 900lpm 40m -NA- -NA-	-NA- -NA- -NA- -NA- -NA- 2 X 450 lpm 40 m -NA- -NA-	MR MR MR MR MR MR MR -NA- -NA-
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA- 900LPM 40m Required Required	-NA- Provided 40m Provided Provided	MR MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA- -NA- -NA- -NA- 25,000 Ltr	-NA- -NA- -NA- -NA- Provided	-NA- -NA- -NA- -NA- MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

ni-17

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			-NA-

The fire protection systems provided in the building were tested, checked at random and found in working competition.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval for signature please

A.K. Malik
29/9/20

Signature of Inspecting Officer
Name:- A.K. Malik
Designation:-DO (NW)

Amr
26/9/20

Signature of Inspecting Officer
Name:- A.K. Sharma
Designation:-ADO (Rohini)

dy.
CFO (WZ)

[Signature]
11/10/2020

[Signature]
DIRECTOR

[Signature]
CFO

[Signature]
1/10



[Signature]
11/10/20

Sirifort institute of Management Studies, Rohini Sector -25, Delhi

Amr/Rodru
FT letter is put up for kind
bearsal and signatures Dear