

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/fireworks/2020/NDZ/ 411

Dated: 09/10/2020

**FIRE SAFETY CERTIFICATE**

Certified that M/s Faquir Chand Sahni Fireworks, located at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06 proposed for running the trade of sale and possession of **manufactured fireworks and Chinese crackers/ sparkles of same category** in quantities and class as specified by the licensing authority, **at ground floor** of a building owned/occupied by **Faquir Chand Sahni fireworks**, was granted **NOC** by this department vide letter No. F6/DFS/MS/FPW/2019/NDZ/6121 dated 14.10.2019. The premises was re-inspected by the officer concerned of this department on 08.10.2020 in the presence of **Mr. Ravinder Sahni (Propriety)** and found that the said Shop has deemed complied with the guidelines issued by Joint Commissioner of Police (Lic.) and that the premises/building is fit for occupancy of **Group J (Hazardous Occupancy) "Fireworks"** with effect from 09/10/2020 for a period of **three years** subject to condition mentioned below.

Issued .....09/10/2020.....at New Delhi by.


  
(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service  
Tel: 011-23414262

**Copy to:-**

1. The Joint Commissioner of police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony, New Delhi
2. M/s Faquir Chand Sahni Fireworks, located at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06

**Condition for the validity of fire safety certificate**

1. Parchatti & basement (Lower ground) should be sealed at all times.
2. All electrical wiring should be properly conduited / concealed/ provided with casing and capping and should be provided with independent isolation mechanism like MCB's at approachable location. No loose wiring/connection is permitted.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. The means of escaped shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
5. No other trade is permitted in the same premises along with the fireworks trade. The licensing authority may kindly ensure that no other activity is allowed during the sale of fire crackers.
6. The NOC/FSC is valid for a period of three years from date of issue. The reference for inspection and subsequent NOC from fire safety point of view shall be made to this department before renewal of the license, clearly stating the period of license for which license is granted/renewed.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

o/c   
09/10/2020

### INSPECTION REPORT

1. Name & address of the building:- M/s Faquir Chand Sahni Fireworks, located at Shop no. 56, Sadar Bazar Chowk, Qutab Road, Delhi-06 and has an approx area of 6 feet by 8.5 feet having basement/lower ground and parchhatti of same size)
2. Type of occupancy:- Group J (Hazardous Occupancy) Fireworks Shop (building is comprised of basement/lower ground & Parchatti)
3. Type of case:- Renewal
4. Details of previous NOC: - No. F6/DFS/MS/FPW/2019/NDZ/6121 dated 14.10.2019
5. Fire safety directives No.- N/A
6. Date of inspection:- 08.10.2020
7. Name of the inspecting officer:- Sh. Rajesh Kumar Shukla ADO, (PWN)
8. Name & designation of officer  
From the building side:- Mr. Faquir Chand Sahni (Owner)
9. Year of construction:- Old Building
10. Applicant's letter No:- 559/Joint CP/Lic. (Expl) Dated 17.09.2020

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site PSS	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	6 mtr.	12 m	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
	A. Number of staircases	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	N/A	N/A	N/A
	B. Width of staircase	NA	NA	NA
	1. Upper floors	NA	NA	NA
	2. Basements	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	NA	NA	NA
	F. Door size	NA	NA	NA
	G. No. of exits	Independent entry and exit required	provided	MR
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	NA	NA
<b>5. Fire Extinguishers</b>				
	1) Total numbers	05 Nos.	05 Nos.	MR
	2) Types	ABC, CO <sub>2</sub>	ABC, CO <sub>2</sub>	MR
	3) ISI marking	Required	Provided	MR

<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
	6) PA system	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	<b>MR</b>

<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Standby Power Supply</b>	N/A	N/A	N/A
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			
	1. No Smoking Signage Board, Sand Bucket & Water Buckets to be provided.		1. Provided	<b>MR</b>
	2. Independent MCB for electrical isolation to be provided.		2. Provided	<b>MR</b>
	3. Electrical wiring to be provided with proper casing and capping.		3. Provided	<b>MR</b>

The fire protection system provided in the building were tested, checked at randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/FPW/2019/NDZ/6121 dated 14.10.2019, renewal under rules 35 of the Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla


Designation ADO (SPM)

DO (CC)



9/x









M.S. 