

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6 / DFS / MS / School/2020/W2/419

Dated: 12/10/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Sr. Sec. School** located at **Adarsh Nagar, Delhi-110033** comprised of **Ground and 03 upper floors** owned/ occupied by **Govt. Girls Sr. Sec. School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2017/School/WZ/1295** dated **28.08.2017** The premise was re-inspected by the officer concerned of this department on **23.09.2020** in the presence of **Smt. Renu Sharma (Vice-Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **12.10.2020** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **12/10/2020** at New Delhi

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph.-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54
2. The Principal, Govt. Girls Sr. Sec. School , Adarsh Nagar, Delhi-110033.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms).
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

n/s

**INSPECTION REPORT**

1. Name & address of the building : Govt. Girls Sr. Sec. School , Adarsh Nagar, Delhi-110033.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (New Building) Ground + 03 upper floors
4. Details of previous NOC : F6/DFS/MS/2017/School/WZ/1295 Dated. 28.08.2017
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 23.09.2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Smt. Renu Sharma (Vice-Principal)
9. Year of Construction : 2017
10. Applicant's letter No. : Online E-Mail I.D dated: 03.09.2020

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	MR
		Accessible	Accessible	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02	02	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50m	1.70m each	MR
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	Required	Provided	MR
f. Door Size	1 m	1.10m	MR	
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA

h

N/6

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	20nos	22nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/Co2	ABC-12/Co2-10	MR
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	ISI Marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02	02each floor	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	30m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA

2

2/7

13	<b>Pumping Arrangements.</b>	<ul style="list-style-type: none"> <li>• Ground Level           <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li>   <li>• Terrace level           <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	<table border="1"> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>450lpm</td><td>450 lpm x 02</td><td>MR</td></tr> <tr><td>40m</td><td>40m</td><td>MR</td></tr> <tr><td>Required</td><td>Provided</td><td>MR</td></tr> <tr><td>Required</td><td>Provided</td><td>MR</td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	NA	NA	NA	NA	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	450lpm	450 lpm x 02	MR	40m	40m	MR	Required	Provided	MR	Required	Provided	MR	<table border="1"> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>450 lpm x 02</td><td></td><td>MR</td></tr> <tr><td>40m</td><td></td><td>MR</td></tr> <tr><td>Provided</td><td></td><td>MR</td></tr> <tr><td>Provided</td><td></td><td>MR</td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	NA	NA	NA	NA	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	450 lpm x 02		MR	40m		MR	Provided		MR	Provided		MR	<table border="1"> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>MR</td><td></td><td></td></tr> <tr><td>MR</td><td></td><td></td></tr> <tr><td>MR</td><td></td><td></td></tr> <tr><td>MR</td><td></td><td></td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	NA	NA	NA	NA	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	MR			MR			MR			MR		
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
NA	NA	NA																																																																																																																								
NA	NA	NA																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
450lpm	450 lpm x 02	MR																																																																																																																								
40m	40m	MR																																																																																																																								
Required	Provided	MR																																																																																																																								
Required	Provided	MR																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
NA	NA	NA																																																																																																																								
NA	NA	NA																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
450 lpm x 02		MR																																																																																																																								
40m		MR																																																																																																																								
Provided		MR																																																																																																																								
Provided		MR																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
NA	NA	NA																																																																																																																								
NA	NA	NA																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
MR																																																																																																																										
MR																																																																																																																										
MR																																																																																																																										
MR																																																																																																																										
14	<b>Captive Water Storage for fire fighting.</b>	<ul style="list-style-type: none"> <li>• Underground tank capacity           <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	<table border="1"> <tr><td>NA</td><td>60,000 ltr.</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>10,000 ltr</td><td>10,000 ltr.</td><td>MR</td></tr> <tr><td>Required</td><td>Provided</td><td>MR</td></tr> </table>	NA	60,000 ltr.	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	10,000 ltr	10,000 ltr.	MR	Required	Provided	MR	<table border="1"> <tr><td>60,000 ltr.</td><td></td><td>NA</td></tr> <tr><td>NA</td><td></td><td>NA</td></tr> <tr><td>NA</td><td></td><td>NA</td></tr> <tr><td>NA</td><td></td><td>NA</td></tr> <tr><td>10,000 ltr.</td><td></td><td>MR</td></tr> <tr><td>Provided</td><td></td><td>MR</td></tr> </table>	60,000 ltr.		NA	NA		NA	NA		NA	NA		NA	10,000 ltr.		MR	Provided		MR	<table border="1"> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>MR</td><td></td><td></td></tr> <tr><td>MR</td><td></td><td></td></tr> </table>	NA			NA			NA			NA			MR			MR																																																																	
NA	60,000 ltr.	NA																																																																																																																								
NA	NA	NA																																																																																																																								
NA	NA	NA																																																																																																																								
NA	NA	NA																																																																																																																								
10,000 ltr	10,000 ltr.	MR																																																																																																																								
Required	Provided	MR																																																																																																																								
60,000 ltr.		NA																																																																																																																								
NA		NA																																																																																																																								
NA		NA																																																																																																																								
NA		NA																																																																																																																								
10,000 ltr.		MR																																																																																																																								
Provided		MR																																																																																																																								
NA																																																																																																																										
NA																																																																																																																										
NA																																																																																																																										
NA																																																																																																																										
MR																																																																																																																										
MR																																																																																																																										
15	<b>Exit Signage.</b>	Required	Provided	MR																																																																																																																						
16	<b>Provision of Lifts.</b>	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	<table border="1"> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	<table border="1"> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	<table border="1"> <tr><td>N/A</td><td></td><td></td></tr> <tr><td>N/A</td><td></td><td></td></tr> <tr><td>N/A</td><td></td><td></td></tr> <tr><td>N/A</td><td></td><td></td></tr> <tr><td>N/A</td><td></td><td></td></tr> <tr><td>N/A</td><td></td><td></td></tr> </table>	N/A			N/A			N/A			N/A			N/A			N/A																																																																	
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A	N/A	N/A																																																																																																																								
N/A																																																																																																																										
N/A																																																																																																																										
N/A																																																																																																																										
N/A																																																																																																																										
N/A																																																																																																																										
N/A																																																																																																																										
17	<b>Standby power supply</b>	N/A	N/A	N/A																																																																																																																						
18	<b>Refuge Area.</b>	➤ Total Area	N/A	N/A	N/A																																																																																																																					

~

2/8

	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated under NBC Part 4, the FSC issued vide letter of even no 1295 dated 28.08.2017 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

*RK*  
*05/10/2018*

Signature of the Inspecting Officer  
Name :- Rajesh Kumar  
Designation:- ADO/RN

*Rajesh Kumar*