

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2020/ 422

Dated: 19/10/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s. Galaxy Automobiles Located at Property No. 28, DLF Industrial Area, Moti Nagar, New Delhi in a building comprised of 03 Basement + Ground + 02 Upper Floors, was issued FSC vide Letter no. F6/DFS/MS/Workshop/2016/WZ/1214 dated 28/11/2016, The premises was re inspected by the officers concerned of this department on 15-09-2020 in the presence of Sh. Pardeep Wadhwa and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Industry" Group G with effect from 19/10/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...19/10/2020... at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Pardeep Wadhwa, M/s. Galaxy Automobiles Located at 69/1A, Moti Nagar, Nafagarh Road, Industrial Area, New Delhi
2. The Asst. Engineer (Bldg.), West Zone, MCD

Following fire safety directives must be adhered to:-

1. **Deviation with regard to construction may be verified by the MCD**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Galaxy Automobiles Pvt. Ltd.,
Located at Property no. 28 DLF Ind. Area Moti Nagar, New Delhi
2. Type of Occupancy : Storage (comprised of three basement
G+02 upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Workshop/2016/WZ/1214
dated 28/11/2016
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2012/3468 dated
21.09.2012
6. Date of inspection : 15-09-2020
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Pardeep Wadhwa
Year of Construction : 2016
9. Applicant's email letter no. : nil dated 23.08.2020

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	2 Provided	M.R.
	• Basements	02	2 Provided	M.R.
	b. Width of staircases			
	• Upper floors	2x1.5 mtr	Provided	M.R.
	• Basements	2x1.5 mtr	1.5m & varies from 1.3m to 1.5m	M.R.(Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	M.R.
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.
	• Water Curtain	Required	Provided	M.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke managements System			
	• Basements	Required	Provided	M.R.
	• Upper floors	Required	Provided	M.R.

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	45 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	M.R. M.R. M.R.
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	Provided Provided Provided	M.R. M.R. M.R.
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Required NA Required Required	Provided Provided NA Provided Provided	M.R. M.R. NA M.R. M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required NA	Provided Provided NA	M.R. M.R. NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 02 Required	Provided Provided Provided	M.R. M.R. M.R.
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	M.R. M.R.
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2850 LPM 60 mtr 01 180 LPM 60 mtr 2850 LPM 60 mtr required required 450 LPM 40 m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R. M.R.
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	1,00,000 ltrs NA Required Required 10, 000 ltrs	Provided Provided Provided Provided Provided	M.R. M.R. M.R. M.R. M.R.
15	Exit Signage	Required	Provided	MR

25/

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. **F6/DFS/MS/Workshop/2016/WZ/1214 dated 28/11/2016** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Sh. Udai Vir Singh
 Designation ADO (WP)

Signature of the Inspecting Officer
 Name
 Designation