

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/Cinema/2020/SZ/ 420

Dated: 15/10/2020

FIRE SAFETY CERTIFICATE

Certified that the **PVR at Select City Walk Mall**, located at **District Centre, Saket, New Delhi**, building comprised of **three tier Basement, Ground+ 07 Upper floors**, auditoriums block having with two tier basement, ground and two upper floors was issued FSC by this department vide letter No. F6/DFS/MS/Cinema/2017/SZ/1130 dated 28/07/2017. The premises was re-inspected by the officer concerned of this department on 05/10/2020 in the presence of Mr. Manish Sati (Manager) and observed that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Assembly Building "Group-D"** with effect from15/10/2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/10/2020 at New Delhi by


Atul Garg
Director
Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Police,(LIC.), 1st floor P.S. Defence Colony, New Delhi 110049
2. The Authorized Signatory, PVR, Select City, District Center, Saket, New Delhi- 110017.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
5. Basement is sealed (brick wall) by the owner.
6. This fire safety certificate may not in any way be treated as regularization (clause 2.8 of UBBI-2016) of unauthorized construction or alteration (Cluase 1.4.3 of UBBL-2016), if any.
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry.

1	Name & Address of the Building	PVR at Select City Walk Mall, Plot no. A-3, District Centre, Saket, New Delhi-110017		
2	Type of Occupancy	Assembly building "Group D" (Cinema)		
3	Building Comprised of	3 Tier Basement, Ground+ 07 Upper floors Auditoriums block having two tier basement, ground and two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Cinema/2017/SZ/1130 dated 28/07/2017		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2004/3084 dated 21/12/2004		
7	Date of Inspection	05/10/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Manish Sati (Manager)		
10	Year of construction	Ground floor (Audi-1 & 2 with projector & snacks stall), 2 nd floor (Audi-3,4,5 & 6 with projector & snacks stall)		
11	Applicant letter No.	Outdoor Diary no: 645 dated 10/08/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC (06/11/2007) Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.	F6/DFS/MS/Mall/2015/SZ/1519 dated 29/08/2015		
	• Road width	Required	As Above	MR
	• Gate width	-N/A-	As Above	-N/A-
	• Width of internal road	-N/A-	As Above	-N/A-
2	Number, width, type & arrangement of exits.	Provided & Maintained by Select City Walk Mall		
	a) Number of Staircase			
	➤ Upper floors	Required	As Above	MR
	➤ Basement floor	-N/A-	As Above	-N/A-
	b) Width of Staircase	Provided & Maintained by Select City Walk Mall		
	➤ Upper floors	Required	As Above	MR
	➤ Basement floor	-N/A-	As Above	-N/A-
	c) Protection of exits	Provided & Maintained by Select City Walk Mall		
	➤ Fire check door	-N/A-	As Above	-N/A-
	➤ Pressurization	-N/A-	As Above	-N/A-
	d) No. of continuous staircase to terrace	Required	As Above	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	Required	1.60 m	MR (old case as approved on plans)
3	Compartmentation.	Provided & Maintained by Select City Walk Mall		
	• Fire check door.	-N/A-	As Above	-N/A-
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-N/A-	As Above	-N/A-
	• Water curtain	-N/A-	As Above	-N/A-
	• Fire dampers.	-N/A-	As Above	-N/A-
4.	Smoke Management system.	Provided & Maintained by Select City Walk Mall		
	• Basement	-N/A-	As Above	-N/A-
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers.	Provided & Maintained by Select City Walk Mall		
	• Total numbers	50nos	68nos	MR

	Types	ABC/CO ₂ /W.CO ₂	38/26/04	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.	Provided & Maintained by Select City Walk Mall		
	• Total numbers on each floor	Hose Reel In each Audi	As Above	MR
	• Length of hose-reel hose.		As Above	MR
	• Nozzle Diameter		As Above	MR
7	Automatic fire detection & alarming system.	Provided & Maintained by Select City Walk Mall		
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	As Above	MR
	• Location of Repeater Panel	-N/A-	As Above	-N/A-
	• Alternate source of power	Required	As Above	MR
	• Hooter's location	Required	As Above	MR
8.	MOEFA	Required	As Above	MR
9.	Public Address System	-N/A-	As Above	-N/A-
10.	Automatic Sprinkler System	Provided & Maintained by Select City Walk Mall		
	• Basement.	-N/A-	As Above	-N/A-
	• Upper floors	Required	As Above	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	Required	As Above	MR
	• Number of Hydrant per floor	Required	As Above	MR
	• Hose box.	Required	As Above	MR
12.	Yard Hydrants.	Provided & Maintained by Select City Walk Mall		
	• Total number of hydrants.	-N/A-	As Above	-N/A-
	• Hose box.	-N/A-	As Above	-N/A-
13.	Pumping arrangements.	Provided & Maintained by Select City Walk Mall		
	• Ground Level			
	➤ Discharge of main pump.	-N/A-	As Above	-N/A-
	➤ Head of main pump.	-N/A-	As Above	-N/A-
	➤ Number of main pumps.	-N/A-	As Above	-N/A-
	➤ Jockey Pump output.	-N/A-	As Above	-N/A-
	➤ Jockey Pump head.	-N/A-	As Above	-N/A-
	➤ Standby Pump output.	-N/A-	As Above	-N/A-
	➤ Standby Pump head.	-N/A-	As Above	-N/A-
	➤ Auto Starting/Manual Stopping.	-N/A-	As Above	-N/A-
	➤ Pump house access.	-N/A-	As Above	-N/A-
	• Terrace Level	Provided & Maintained by Select City Walk Mall		
	➤ Discharge of pump.	Required	As Above	MR
	➤ Head of pump.	Required	As Above	MR
	➤ Power supply.	Required	As Above	MR
	➤ Auto starting of pump.	Required	As Above	MR
14.	Captive water storage for firefighting.	Provided & Maintained by Select City Walk Mall		
	• Underground tank capacity.	-N/A-	As Above	-N/A-
	➤ Draw-off connection.	-N/A-	As Above	-N/A-
	➤ Fire Service Inlet.	-N/A-	As Above	-N/A-
	➤ Access to tank.	Required	As Above	MR
	• Overhead tank capacity.	Required	As Above	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-N/A-	As Above	-N/A-
		-N/A-	As Above	-N/A-
		-N/A-	As Above	-N/A-
		-N/A-	As Above	-N/A-
		-N/A-	As Above	-N/A-
17	Standby Power Supply	Required	As Above	MR
18.	Refuge Area	Provided & Maintained by Select City Walk Mall		
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19.	Fire Control Room.	Provided & Maintained by Select City Walk Mall		
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required	As Above	MR
		-N/A-	As Above	-N/A-
		Required	As Above	MR
		Required	As Above	MR
		-N/A-	As Above	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	CO2 flooding provided near electrical panel	MR
Earlier the FSC was issued to PVR at Select City Walk Mall with Details of Seating Capacity & Exits as below:-				
Seats: <u>Audi-1</u> Audi-2 Audi-3 Audi-4 Audi-5 Audi-6				
40 40 345 395 164 168				
Exit: 3 3 6 6 3 4				
As per letter no. F.6/DFS/MS/BP/2017/3360 dated 11/12/2017 & C/2 (part file) now details of Seating Capacity & Exits is as below:-				
Seats: <u>Audi-1</u> Audi-2 Audi-3 Audi-4 Audi-5 Audi-6				
40 40 345 299 164 168				
Exit: 3 3 6 5 3 4				

The fire protection systems provided in the building were test checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Cinema/2017/SZ/1130 dated 28/07/2017, ^{(placed at Chap 6) see} renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended

Accordingly DFA is put up for approval and signature please.

Avtar Singh
08/10/2020

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (MR)

If Report of FSC in re to M/s Select City Mall is placed on file (C/213 to C/27/17).

Rivind
09/10

DO(SD)

CFP

ADMR

FI PL

ADMR