

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/Cinema/2016/NDZ/ 417

Dated: 13/10/2020

FIRE SAFETY CERTIFICATE

Certified that Ritz Cinema, located at Kashmere Gate Delhi- 06 comprised of **Ground + One upper floor** was granted **NOC** by this department vide letter no. F6/DFS/MS/2019/Cinema/6268 dated 21.10.2019. The premises was re-inspected by the officer concerned of this department on **28.09.2020** in the presence of Mr. Vijay Narayan Seth (Owner) and found that the said cinema hall has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy of **group D "Assembly (cinema) Occupancy"** with effect from 13/10/2020 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, mentioned below.

Issued 13/10/2020at New Delhi by.


Sunil Chaudhary
Dy. Chief Fire Officer
Delhi Fire Service
Tel:-011-23414152

Copy to:-

1. The Joint Commissioner of police (Licensing),
1st Floor, P.S. Defense colony, New Delhi
2. The Manager/Owner, Ritz Cinema, Kashmere Gate, Delhi-110006

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escaped shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- Ritz Cinema, located at Kashmere Gate Delhi- 06
2. Type of occupancy:- Assembly (Ground + One Upper floor)
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/2019/Cinema/6268 dated 21.10.2019
5. Fire safety directives No.- N/A
6. Date of inspection:- 28.09.2020
7. Name of the inspecting officer:- Sh. Rajesh Kumar Shukla (ADO/PWN)
8. Name & designation of officer
From the building side:- Mr. Vijay Narayan Seth (Owner)
9. Year of construction:- Old Building
10. Applicant's letter No:- E-mail Dated 23.09.2020

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per previous Inspection	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	More than 06 mtr	MR
	2) Gate width	-----	Directly accessible from the road	M/R
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.25 m, 1.25 m	MR (Old Case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	NA	NA	NA
	F. Door size	1.5 mtr	1.6 m	MR
	G. No. of exits	10 no.	10 no.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers			
	1) Total numbers	14 Nos.	Provided	MR
	2) Types	ABC, water CO ₂ , CO ₂	Provided	MR
	3) ISI marking	Required	Provided	MR

86

6.	First-Aid Hose Reel			
	1) Total number of each floor	03 Nos.	2 no. at Ground 1 no. at balcony (first floor)	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Beam detector	Provided	MR
	2) Location of main panel	Required	Provided at 1 st floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	DG Set (62KV)	MR
	5) Hooter's Location	Audible location	Provided in first floor Balcony Area	N/A
	6) PA system	Required	Provided in projector room	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	01 no.	01 no	MR
	2) Hose box	01 no.	01 no.	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	14000 ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	DG set(62 KV)	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Lightning Arrester required to be provide in the building			Provided

The fire protection system provided in the cinema hall were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2019/Cinema/6268 dated 21.10.2019, renewal under rules 35 of the Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CC)



17/11/2020

Dy. CTO (MS2)





M.S. - 