

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2020/NDZ/437

Dated: 20/10/2020

FIRE SAFETY CERTIFICATE

Certified that the EDMC Pratibha Vidyalaya, Baldev Park, Delhi-51, comprised of ground plus one upper floor was issued FSC vide letter No. F.6/DFS/MS/School/2016/788 Dated-17/05/16. The school building was inspected by the officer concerned of this department on 04/10/20 in the presence of Smt. Minakshi (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground +1floor only with effect from 20/10/2020 for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....20/10/2020.....at New Delhi by



(Sunil Chawdhary)
Dy.Chief Fire Officer



To,

The Principal, (Ist Shift)
EDMC Pratibha Vidyalaya, Baldev Park, Delhi-51.

Copy to:-

1. The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-92.
2. The Principal, (IInd Shift)
EDMC Pratibha Vidyalaya, Baldev Park, Delhi-51.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/4

1. Name & address of the building : EDMC Pratibha Vidyalaya, Baldev Park, Delhi-51.
2. Building is comprised of : G+1 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2016/788 Dated-17/05/16
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398dt 01.03.2011
7. Date of Inspection : 05/10/2020
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of
Officer from the building side : Smt. Meenakhi (Principal)
10. Year of Construction : 2004
11. Applicant's letter No : Dated 12/09/20

| N O | Minimum Standards on fire prevention and fire safety U/R33 | Circular Requirement | Provided at Site | Remarks |
|--------|--|----------------------|------------------|---------|
| 1 | Access to building | | | |
| | • Road width | 06 m | 06 m | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor | 2 no. | 2 no. | MR |
| | • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | • Upper Floor | 1.5 m | 1.5 m each | MR |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | 1 no. | 1 no. | MR |
| | e. Width of Corridor | 1.5 M | 1.5 M | MR |
| | f. Door Size | 1.0 M | 1.0 M | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 5 Nos. | 5 Nos. | MR |
| | • Types | ABC & Co2 | ABC & Co2 | MR |
| | • IS marking | ISI marked | ISI marked | MR |

| | | | | |
|----|---|-----|----------|-----|
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | Provided | MR |
| 9 | Public address System. | N/A | Provided | MR |
| 10 | Automatic Sprinkler System. | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | N/A | N/A | N/A |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | N/A | N/A | N/A |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | N/A | N/A | N/A |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace Level | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the Pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | N/A | N/A | N/A |

N/13

| | | | | |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts. | N/A | N/A | N/A |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | N/A | N/A | N/A |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | N/A | N/A | N/A |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2016/788 Dated 17/05/16 renew under the circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

R.K. Yadav
Signature of the Inspecting Officer

Name:-R.K.Yadav
Designation:-ADO (LN)

DO(ED) *[Signature]*
[Signature]
DY, CFO/MS/2016/788

F. T. Jais
[Signature]
9/10

[Signature]

[Signature]

F. T. Jais is prepared and put up for signature

Please.

DY, CFO/MS/2016/788

[Signature]