

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2020/ 435

Dated: 20/10/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Co-ed Sec School, P-Block, Sultan Puri, Delhi-110086**, comprised of **03 Blocks, A Block Gr.+ One upper floor, B & C Blocks Ground floor only** owned/occupied by **Govt. Co-ed Sec School** was issued fire safety certificate by this department vide letter no **F6/DFS/MS/2017/WZ/1399 dated 22.09.2017**. The premises was re-inspected by the officer concerned of this department on **15.09.2020** in the presence of **Smt. Uma (HOS)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **class "B" Educational Buildings** with effect from **20 / 10 /2020** for a period of **three years** subject to compliance of the conditions mentioned below.

Issued on **20/10/2020** at New Delhi by

  
**(Dhrampal Bhardwaj)**  
**Dy.Chief Fire Officer**  
**Tel;-01123414250**

**Copy to:**

1. The Principal, Govt. Co-ed Sec School, P-Block, Sultan Puri, Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



2. Type of Occupancy : Educational
3. Type of Case : Renewal (03block-A block Ground +01,B & C Ground floor only)
4. Details of Previous NOC : F6/DFS/MS/2017/WZ/1399 dated 22.09.2017
5. Fire Safety directives letter No : Direction of Education dated 01/03/2011
6. Date of inspection : 15.09.2020
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers  
From the building side : Smt. Uma (HOS)
9. Year of Construction : 1996
10. Applicant's letter No. : Online mail dated 17.08.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible	6.0 mtr	MR
		4.5m	3.75m & 1.35m	MR(Old case)
		NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 NA	02 NA	M.R NA
	b. Width of staircases	1.50 mtr	1.45 mtr each	MR(Old case)
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	NA NA	NA NA	NA NA
	c. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1.10m x 2	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA NA	NA NA
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	22 No's ABC/CO2 ISI Marked	25 No's ABC/CO2 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
		NA	NA	NA



	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA NA	NA NA	NA NA
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	NA	NA	NA
<b>9.</b>	<b>Public Address System</b>	NA	NA	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	MR
		NA	NA	MR
		NA	NA	MR
		NA	NA	NA
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>17.</b>	<b>Standby power supply</b>	NA	NA	NA
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> </ul>	NA	NA	NA



N/18

	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2017/WZ/1399 dated 22.09.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*Ajay*  
11/10/2020

Signature of the Inspecting Officer  
Name           Ajay Kumar Sharma  
Designation   ADO (Rohini)

~~DCFO (WZ)~~

*[Signature]*  
18/10/2020

~~ADDO Rohini~~

FT letter is put up for kind perusal and  
Signature please.

*[Signature]*  
19/10/2020

~~DCFO (WZ)~~

*[Signature]*  
19/10/2020

ms/ull