

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE  
NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2020/ 439

Dated: 20/10/2020

FIRE SAFETY CERTIFICATE


Certified that the Govt. Girls Sr. Sec. School at School Block, Shakarpur, Delhi-92, owned/occupied by Govt. Girls Sr. Sec. School, comprised of ground plus one upper floor was granted FSC vide letter No. F.6/DFS/MS/School/2017/1878 dated 28/12/17. The school building was re-inspected by the officer concerned of this department on 13/10/20 in the presence of Mrs. Reeta Kathuria (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/cc/Fire Safety/2011/3298 to 3398 dated 01/03/11 and found that the building is fit for occupancy class B "Educational Building" with effect from 20/10/2020 for a period of **three years**, subject to conditions printed overleaf.

Issued on 20/10/2020 at New Delhi by



(Sunil Chawdhary)

Dy. Chief Fire Officer



To,

The Principal,  
Govt Girls Sr. Sec. School,  
School Block, Shakarpur, Delhi-92.

Copy to:-

1. The Dy. Director of Education  
D-Block, AnandVihar, Delhi-92.
2. The Principal,  
Govt. Boys Sr. Sec. School,  
School Block, Shakarpur, Delhi-92.

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : GGSS School Block, Shakarpur, Delhi-92.
2. Building is comprised of : Ground plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2017/1878 dated 28/12/17
6. Fire Safety direction letter No : F.16/Estate/cc/Fire Safety/2011/3298 to  
3398 dated 01/03/11
7. Date of Inspection : 13/10/20
8. Name of the Inspecting officers : DO F. Brown
9. Name and designation of Officer  
from the building side : Mrs. Reeta Kathuria (Principal)
10. Year of Construction : 1995
11. Applicant's letter no. : Nil dated-24/09/20

S. N. O.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	08 m	MR
	• Gate width	4.5 M	5 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos	03 Nos	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor			
	• Basement	1.5 m	1.5 m each	MR
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door			
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.5 m	1.5 m	MR
		1.0 M	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	11 nos.	16 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• ISI marking	ISI marked	ISI marked	MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>upper floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting /Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of the Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2017/1878 dated 28/12/20 it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*[Handwritten Signature]*  
13/17

Signature of the Inspecting officer  
Name : F. Brown  
Designation : DC (ED)

DY. CFO/MS

F.t. please

*[Handwritten Signature]*  
13/17

~~*[Handwritten Signature]*~~

~~DC (ED)~~

F.t. letter is prepared and put up for signature plan

DY. CFO/MS

*[Handwritten Signature]*  
10/17

*[Handwritten Signature]*  
14/17