

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/Hospital/2020/SZ/ 498

Dated: 22/10/2020

FIRE SAFETY CERTIFICATE

Certified that the building of MKW Hospital, J-Block, Community Centre, Rajouri Garden, New Delhi-110027, is comprised of basement, ground floor plus three upper floors, was issued FSC by this department vide letter F.6/DFS/MS/Hospital/2016/SZ/459 dated 23.03.16. The building was re-inspected by the officers concerned of this department on 13.10.2020 in the presence of Dr. Ashish Bawa and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Institutional" (Hospital Building) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 22/10/2020 at New Delhi.


ATUL GARG
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director,
MKW Hospital, J-Block, Community Centre,
Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. In case of usage of terrace floor for any other purpose than building services, then the FSC will be null and void.

INSPECTION REPORT

1. Name & address of the building : MKW Hospital, J-Block, Community Centre, Rajouri Garden, New Delhi-110027
2. Type of Occupancy : Institutional (Hospital Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/Hospital/2016/SZ/459 dated 23.03.16
5. Fire Safety directives letter No : F6/DFS/MS/94/Hospital/1133 dated 01.8.94
6. Date of inspection : 13.10.2020
7. Name of Inspecting Officer : D.O M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Dr. Ashish Bawa
9. Year of Construction : 1994
10. Applicant's letter No. : email letter dated 02.09.2020


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 05 mtrs. N/A	12 mtrs 05 mtrs. N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 no.	02 no.'s	M/R
		01 no.	02 no.'s	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	Old case	125 & 100 cms	MR
		Old case	125 & 92 cms	MR
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
		2.04	210 cms	MR
	e. Width of Corridor	Old case	100 cms	M/R, being old case
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	30 no.'s	Provided	M/R
		ABC/WCO ₂ / CO ₂ type	Provided	M/R
		ISI marked	Provided	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One in each floor	Provided	M/R
		30 m	Provided	M/R
		5 mm	Provided	M/R

Automatic fire detection and alarming system				
7.	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		N/A	Ground floor	M/R
		N/A	N/A	N/A
		Required	Provided	M/R
		N/A	Near staircase	M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	One	100 mm	M/R
		One	One	M/R
		One	One	M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900LPM & 180 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	30000 ltrs.	30000 ltrs.	M/R
		Required	Provided	MR
		Required	Provided	M/R
		Required	Provided	M/R
		12500 Ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		Required	Provided	M/R
		N/A	Provided	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19.	Fire Control Room <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings communicated by this department vide letter no. F.6/DFS/MS/Hospital/2020/SZ/ 2351 dated 22.09.2020 have been complied.

In view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/Hospital/2016/SZ/459 dated 23.03.16 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


14/10/2020

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer



13/10/2020


Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

302/200/2020
14/10/2020


Dy.C.F.O (South Zone)
Chief Fire Officer





24/10


21/10/20

As approved, FT is put up for Kend perused and

Separate pl.
Dy. C.F.O. / 
21/10/20


21/10/20
Asstt. Div. Officer

m