

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2020/ WZ/ 433

Dated: 27/10/2020

FIRE SAFETY CERTIFICATE

Certified that the Haldiram's located at Ground Floor & Basement (Storage), 17-A, Industrial Area, Najafgarh Road Moti Nagar, New Delhi-110015 in a building comprised of Basements, Ground Floor, 1st Floor & 2nd Floors, owned / occupied by Haldiram's Products Private Limited, has already been issued Fire Safety Certificate vide Letter No. **F6/DFS/MS/EH/2017/WZ/1444 dated 04/10/17** for assembly occupancy. The premises / Building was re-inspected by the officer concerned of Fire Service on 20.10.2020 in the presence of Mr. Sudhir Sharma & Udit Awasthi and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition and found that building / premises have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group - D) with effect from 27/10/2020 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 27-10-2020 at New Delhi.


(DHARAMPAL BHARDWAJ)
DY. CHIEF FIRE OFFICER

Copy to :-

1. Authorized Signatory, Haldiram's Products Private Limited, 17-A, Industrial, Najafgarh Road, Moti Nagar, New Delhi-110015.
2. Addl. Commissioner of Police (Lic.), PS Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. **Fire Safety Certificate valid from Basement & Ground floor only.**
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. Basements shall be used strictly as per Building-By-Laws.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **17-A, Industrial Area, Najafgarh Road, Moti Nagar, New Delhi-110015.**
2. Type of Occupancy : **Assembly**(Restaurant at GF only. Basement for storage in the name of Haldiram's)
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/EH/2017/WZ/1444 dated 04/10/17**
5. Fire Safety directives Letter No. : **F6/DFS/MS/BP/2014/1702 dated 25/07/2014**
6. Date of inspection : **21/10/2020**
7. Name of the Inspecting Officer : **A.D.O. (Jwp)**
8. Name and designation of Officer
from the building side : **Sh. Sudhir Sharma & Udit Awasthi**
9. Year of Construction : **2010**

10. Applicant's letter No. : MHA Portal ID-20200929164732 Dated 29/09/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtr	60 mtr	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	As per sanction plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	1.50 Mtr	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	1.50 mtr	Halls Only	MR
	f. Door Size	2.00 mtr x 2 for restaurant	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10	12	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R




	<ul style="list-style-type: none"> Total numbers on each floor 	2	2	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	G. Floor	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	NR	Provided	NR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required if basement have ceiling	No ceiling in basement	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	150 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	2	MR
	<ul style="list-style-type: none"> Hose Box 	2	2	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	4	4	MR
	<ul style="list-style-type: none"> Hose Box 	4	4	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	➤ Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	50 MH	50 MH	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	50 MH	50 MH	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	50 MH	50 MH	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	50 MTR	50 MTR	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	50,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/EH/2017/WZ/1444** dated **04/10/17** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/COB) on M/R
By CFO/COZ)


22/X/2020

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Ashok Jaiswal
F.T. is added for Seps. please.
By CFO/COZ)

23/10/2020


26/X/2020

ms/ell

27/10/2020