

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2020/ W2/442

Dated: 22/10/2020

FIRE SAFETY CERTIFICATE

Certified that the **SBM Senior Secondary School** located at **Shivaji Marg, New Delhi – 110015** comprised of Ground & 03 Upper Floors was earlier issued Fire Safety Certificate vide Letter No. F6/DFS/MS/School/2017/WZ/1512 Dated 23-10-17. The premises was re inspected by the officer concerned of this department on 06/10/2017 in the presence of Dr. Preeti Shukla (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 – 362 Dated 17/01/2005 and that the premises is fit for occupancy class “Educational” Group B with effect from 22/10/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/10/2020 at New Delhi by.


DHARAMPAL BHARDWAJ
DY.CHIEF FIRE OFFICER.

Copy to:

1. Dr. Preeti Shukla (Principal), SBM Senior Secondary School, Shivaji Marg, New Delhi – 110015.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: SBM Senior Secondary School, Shivaji Marg, New Delhi – 110015.
2. Type of Occupancy : Educational (Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/1512 Dated 23-10-17
5. Fire Safety directives Letter No. : DOE Circular No. 262-362 dated 17-01-2005
6. Date of inspection : 08-10-2020
7. Name of the Inspecting Officer : A.D.O.(JWP)
8. Name and designation of Officer
from the building side :Dr. Preeti Shukla (Principal)
9. Year of Construction : 2000
10. Applicant's letter received through Email ID principalsbmshivajimarg@gmail.com
dated 24/09/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cr.No. 262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	On main road	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	2 mtr x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	5,000Ltr	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2017/WZ/1512 Dated 23-10-17 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO (C/D)

[Handwritten signature]
9/11/2020

D. 10/11/21

[Handwritten signature]
31/11/2020

Signature of the Inspecting Officer
Name Ashok Kumar Jaiswal
Designation ADO (JWP)