

Frequent hand sanitization-wearing of face mask-keep physical distance to prevent from Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2020/SZ / 474

Dated: 5/11/2020

FIRE SAFETY CERTIFICATE

Certified that the **Aakash International School**, G-2 Block, Jai Vihar, New Delhi-110043, comprised of basement having storage in hall, ground floor plus three upper floors, having total 44 rooms (Including Classrooms, Library, Labs & Offices etc.) was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2017/SZ/1275 dated 24.08.17 owned/occupied by Aakash International School. The school building was re-inspected by the officer concerned of this department on 22.10.2020 in the presence of Smt. Promila Gupta (Principal) and found that the Aakash International School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 5/11/2020 at New Delhi.

(SUNIL CHOWDHARY)
Dy. CHIEF FIRE OFFICER
SOUTH ZONE

Copy to:-

1. The Manager,
Aakash International School,
G-2 Block, Jai Vihar, New Delhi-110043
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

7/11/2020
04/11/2020

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Aakash International School, G-2 Block, Jai Vihar, New Delhi-110043.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2017/SZ/1275 dated 24.08.17
5. Fire Safety directives letter No : N/A
6. Date of inspection : 22.10.2020
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers : Smt. Promila Gupta (Principal)
- From the building side : 2016-17
9. Year of Construction : AIS/Fire/Renewal/800 dated 08.09.2020 & Form "J" & "K"
10. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5 mtrs N/A	5.5 mtrs 4.65 mtrs N/A	M/R, being old case MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 no.'s	02 no.'s	M/R
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s	03 no.'s	M/R
	b. Width of staircases	150 cms	180 & 150 cms	M/R
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms	275, 180 & 155 cms	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	M/R
	e. Width of Corridor	150 cms.	300 cms.	M/R
	f. Door Size	100 cms	100 cms (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required	Exhaust fans are provided	M/R
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 no's ABC/CO ₂ type	Provided	M/R
			Provided	M/R
		ISI marked	Provided	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose 	One 30 mtrs 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		900 LPM	Provided	M/R
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		15000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

N/A

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2017/SZ/1275 dated 24.08.17 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
29/10/2020

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

Divisional Officer (South West) ← on c/c

367/DO/BW
29/10/2020

CFD

29/10

21/11/20 *FF PH*

20/11/20

FT. letter is put up for signature please

Sandeep
01/11/2020

Dy. Insp. (S.W.)

21/11

