

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2020/NDZ/ 107

Dated 21/07/2020

FIRE SAFETY CERTIFICATE

Certified that the **Bikanervala Restaurant** running at FF, F -116 & 117, building comprised of ground plus three upper floors named Aditya Arcade, Community Centre, Preet Vihar, Delhi was granted FSC vide letter No. F6/DFS/MS/EH/2014/NDZ/1198 Dated 11/08/17, owned/occupied by M/s Bikanervala Foods Pvt.Ltd. have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 26/07/17 in the presence of **Sh. Manoj Jha (Manager)** and found that the building is fit for occupancy Group-D Assembly building(Restaurant) with effect from 21/7/2020 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 21/07/2020 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service
o/c

To,

The Dy.Health Officer
East Delhi Municipal Corporation
Health Department, Karkardooma,
North Zone, Shahdara, Delhi.

Copy to:-

M/s Bikanervala Foods Pvt.Ltd.
A-28, Lawrence Road, Industrial Area,
New Delhi -110035.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Bikanervala Restaurant, at FF, F -116 & 117, Aditya Arcade, Community Centre, Preet Vihar , Delhi-92,
2. Building Comprised of : G+3 (Restaurant running at first floor only)
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2017/NDZ/1198 Dated 11/08/17
5. Fire Safety directives No : NBC Part-IV
6. Date of Inspection : 16/07/2020
7. Name of the Inspecting Officer : ADO R.K.Yadav
8. Name of the designation of Officer
From the building side : Sh. Manoj Jha (Manager)
9. Year of Construction : 2001
10. Applicant's letter No : Dated 23/06/2020

	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 M N/A N/A	18 M N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 No N/A	02 Nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M N/A	1.5 M & 1.0 M N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtr.	2.0 M & 1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A Required N/A N/A	N/A Sealed N/A N/A	N/A MR N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	05 nos. ABC & Co2 ISI marked	06 Nos. ABC & Co2 ISI marked	MR MR MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers of each floor • Length of hose reel hose • Nozzle diameter 	1 no. 30 m 5 mm	1 no. 30 m 5 mm	MR MR MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• basement	N/A	N/A	N/A
	• upper floors	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 & 180 LPM	MR
	➤ Head of the Pump	40 M	40M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/15

19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Rules the FSC issued vide Letter No-F6/DFS/MS/EH/2014/NDZ/1198 Dated 11/08/17 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name : R.K.Yadav

Designation : ADO(LN)

DO (ED)
[Signature]
20/7

DO CFO (NDZ)
[Signature]
20/7

F.d. plans -
[Signature]
20/7

ADO L - N.

FT Letter is put up for signature
[Signature]

DO CFO (NDZ)
[Signature]

M.S. cell
[Signature]