

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2020/WZ/

459

Dated: 04 / 11 / 2020

FIRE SAFETY CERTIFICATE

Certified that the Global Ceramics Pvt. Ltd. located at Plot No. H-16, Udyog Nagar, Rohtak Road, Delhi-110041 comprised of Two Basements, Ground Floor, First Floor & Second Floor only owned / occupied by Global Ceramics Pvt. Ltd. has already been issued FSC by this department vide letter No. No. F6/DFS/MS/2015/WZ/393 dated 20/03/2015. The premises was re-inspected by the officer concerned of Fire Service on 26.10.2020 in the presence of Mr. Sunny Singh and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Industrial" with effect from 04 / 11 / 2020 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 04/11/2020 at New Delhi by.

(DHARAMPAL BHARDWAJ)
DY.CHIEF FIRE OFFICER.

Copy to :-

1. Mr. Sunny Singh, Global Ceramics Pvt. Ltd. located at Plot No. H-16, Udyog Nagar, Rohtak Road, Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

4/6
INSPECTION REPORT

1. Name & address of the building: Plot No. H-16, Udyog Nagar, Rohtak Road, Delhi- 110041
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/393 dated 20/03/2015
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2012/1568 dated 2/05/2012
6. Date of inspection : 26/10/2020
7. Name of the Inspecting Officer : A.D.O. (Jwp.)
8. Name and designation of Officer from the building sid : Mr. Sunny Singh
9. Year of Construction : 2013-2014

Two Basements + Ground Floor + Two Upper Floors only
--

Plot Area :- 1019.23 M ² Covered Area on Ground to Second Floor each :- 461M ²

10. Applicant's letter received through Email ID-global@glocera.com dated 13/10/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	15 mtr.	Provided	MR
	• Gate width	4.5 mtr.	Provided	MR
	• Width of internal road	As per sanction Plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.50 mtr.	Provided	MR
	• Basements	1.50 mtr.	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	NA	Halls Only	NA
	f. Door Size	1.00 mtr.	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	18	25	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

(Handwritten Signature)

6.	First – Aid Hose Reels			
	• Total numbers on each floor	Two at each Floor	Provided	MR
	• Length of hose reel hose	30mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Alternate Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At each floor	Provided	MR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Two at each floor	Provided	MR
	• Hose Box	Two at each floor	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	40 MH	65 MH	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	40 MH	65 MH	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	40 MH	65 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 Ltr.	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR

N18

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- MCB / ELCB and metal conduit wiring (Concealed wiring), earth leakage circuit breaker have been Provided.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2015/WZ/393 dated 20/03/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO (CD) on MR
By CFO (CZ)

[Signature]
28/1/2020

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

[Signature]
A.D.O. Jwala Puri

F.T. is put up for sign. please.

By CFO (CZ)
M.S. (cell)

[Signature]
3/11/2020

M.S. cell