GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020 / W2/EH/158 Dated: 05/ 11 /2020

FIRE SAFETY CERTIFICATE

Certified that the **M/s Jubliant Foodworks Limited (Domino's Pizza Restaurant) located at GF, Property no. F-14/12, Model Town, Part- II, Delhi-09** in the building comprised of ground and 02 upper floors owned/ occupied by **M/s Jubliant Foodworks Limited Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of Fire Service on 06.10.2020 in the presence of **Sh. Piyush Sharma, Manager** and that the building/ premise is fit for occupancy Class **Assembly** restarant at upper ground floor only with effect from 05/11/2020 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/11/2020. at New Delhi by

(Atul Garg)
Director
Ph-011-23414000

Copy to:-

1. M/s Jubliant Foodworks Limited Restaurant, S.No. 14/12, GF, Model Town, Part-II, Delhi-09.
2. The Dy. Health Officer, NDMC, Public Health Department City S.P.Zone, Old Hindu College, Kashmere Gate, Delhi.
3. Addl. CP/Lic. Defence Colony, Delhi(The information provided to this department vide your letter dated 23.07.19(overleaf)

Conditions for the validity of Fire Safety Certificate:

1 All the means of escape/entry/exit shall be kept free from any obstruction.
2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3 All the staff members must know the correct method of operation of firefighting system.
4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms.
5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Jubliant Foodworks Limited Restaurant, S.No. 14/12, GF, Model Town, Part-II, Delhi-110009.
2. Type of Occupancy : Assembly (Ground floor only) G+02 upper floor
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 06.10.2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr Piyuah Sharma
9. Year of Construction : 2005 (Residential) as per online application
10. Applicant's letter No. : Online I. D. no. 20200919071l4 dated 21.09.2020

	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC requirement	Provided at site	Remarks MR/NMR
1	**Access to building**			
	• Road width	09m	12m approx...	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	**Number, Width, Type & Arrangement of Exits (Restaurant at GF only)**			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	80cm	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2m & 1.50m	2.0m & 1.50m	MR
3	**Compartmentation.**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/S

4	**Smoke Management System.**			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	**Fire Extinguishers**			
	• Total numbers	05nos	06nos	MR
	• Types	ABC/Co2	ABC-5 Co2-1	MR
	• ISI marking	Yes	Yes	MR
6	**First-Aid Hose Reels.**			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	**Automatic fire detection and alarming system.**			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	**MOEFA**	Required	Provided	MR
9	**Public Address System.**	NA	NA	NA
10	**Automatic Sprinkler System.**			
	• Basement	NA	NA	NA
	• Upper Floor(Ground floor)	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants**			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	**Yard Hydrants.**			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	**Pumping Arrangements.**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A

	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450lpm	Provided provided at adjoining building	MR
	➢ Head of the pump	40m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	**Captive Water Storage for fire fighting.**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltr	20,000 ltr. provided at adjoining building	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	**Standby power supply**	Required	Provided	MR
18	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A

N/S

	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection..

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

13/10/2020

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation: - ADO/RN

Dy CFO/WZ

What about letter No - 2018/GH/41 dated 3/1/18 placed at C-4

15/10/2020

ADO/RN

Spoken, case is received on MHA Portal online. as requested at C/4.

Submitted PL

15/10/2020

Dy CFO/WZ

15/10/2020

CFO

20/10

FIRE SERVICE Chief Fire Officer 20/10/20 631

21/10/2

ADO/RN

As approved, F.I. letter is put up for your signature PL

22/10/2020