

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001

NO.F6/DFS/MS/School/2020/SZ/ 470

Dated: 5/11/2020

FIRE SAFETY CERTIFICATE

Certified that the N R Public School, located at RZF-764, Near DESU Office, Raj Nagar Part-II, New Delhi-110077, comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1322 dated 5.9.2017. The said school building was re-inspected by the officer concerned of this department on 15.10.2020 in the presence of Sh. Jaya Bhaisora (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules 2010, and that the premises/building is fit for occupancy class B "Educational building" with effect from 5/11/2020... for a period of **three years**, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on 5/11/2020 at New Delhi by



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)

or

Copy to:-

1. Director (Education), Govt. of NCT of Delhi, old Secretariat, Delhi-110054.
2. The Principal, N R Public School, located at RZF-764, Near DESU Office, Raj Nagar Part-II, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Palam Colony, New Delhi-110045		
2	Type of Occupancy	Educational Building "B" (Ground + Three Upper Floors)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/School/2017/1322 dated 05.9.2019		
5	Fire safety directives letter No	Nil		
6	Date of inspection	15.10.2020		
7	Name of the inspecting Officers :	S.P. Bhardwaj ADO (Dwarka)		
8	Name and designation of officers from the building side	Sh. Jaya Bhasora (Principal)		
9	Year of construction	Ground & First Floor 2006 Second & Third Floor January 2009		
10	Applicant's letter No.	email dated 18.9.2020	ground plus three upper floors	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE letter dated 1.3 2011	Provided at site	Remarks MR / NMR
--------	-------------------------------------------------------------	---------------------------	------------------	------------------

1	Access to building			
	1) Road width	6 Mtr.	6 Mtrs.	MR
	2) Gate width	4.5 Mtr.	Direct accessible from road	M/R
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. & .75 Mtrs.	1.50 & 1.10 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR
	e. Width of corridor	N/A	1.83 Mtrs.	N/A
	f. Door size	1 Mtrs.	1 Mtrs.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		Natural Ventilation	MR

5	Fire Extinguishers			
	total numbers	2 Nos. at each floor CO2 ABC	10 Nos. ABC	MR MR

4/18

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	30 Mtrs.	30 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

11/20

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric pannel	MR		

Fire protection systems provided in the building were checked/tested and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules renewal of FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/1322 dated 5.9.2017 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
15/11/20
S.P. Bhardwaj
ADO (Dwarka)

Dd/SW

Director
18/11/2020
[Signature]
28/11/20

ADO/DWARKA

Sir, since Defo S2 has joined duty the case may please be sent to Defo S2 for approval please.

[Signature]
21/11/20

Dd/SW
[Signature]
3/11/2020

Defo (S2)
[Signature]
F.t. please.