

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/Indl./2020/SZ/ EH/154

Dated: 05 / 11 / 2020

FIRE SAFETY CERTIFICATE

Certified that **M/s Taj Sats Air Catering Ltd., Located at IGI Airport Complex, New Delhi-110037**, comprised of Basement, Ground plus one upper floor only owned/occupied by Taj Sats Air Catering Ltd., was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Club/SZ/2017/1373 dated 18/09/2017. The premise was re-inspected by the officer concerned of this department on 10/10/2020 in the presence of Mr. Harendra Goyal and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class G "**Industrial**" (**Flight Kitchen**) with effect from 05 / 11 / 2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 05 / 11 / 2020 at New Delhi by


Sunil Chawdhary
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Health Department, SDMC, Najafgarh, New Delhi.
2. The Chief Engineer, M/s Taj Sats Air Catering Ltd., Located at IGI Airport Complex, New Delhi-110037.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Any deviations with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Taj Sats Air Catering Ltd., Located at IGI Airport Complex, New Delhi-110037		
2	Type of Occupancy	Class "G" (Industrial Occupancy i.e. Flight Kitchen)		
3	Building Comprised of	Ground + 01 Upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Club/SZ/2017/1373 dated 18/09/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	10/10/2020		
8	Name of the Inspecting Officers	DO S.K. Dua		
9	Name & Designation of Officers from the building side	Mr. Harendra Goyal		
10	Year of construction	1983		
11	Applicant letter No.	Letter No. Nil dated 03/09/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements as per old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	6 m	9 m	MR
	➤ Gate width	4.5 m	5m	MR
	➤ Width of internal road	Required	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos.	02 Nos.	MR
	➤ Basement floor.	01 No.+ 01 Ramp	01 No.+ 01 Ramp	MR (old case)
	b) Width of Staircase			
	➤ Upper floors	Required	1.18 m (each)	MR (old case)
	➤ Basement floor	Required	1.19 m & ramp=3.20m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d)No. of continuous staircase to terrace	01 No.	01 No.	MR
	e)Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust Fans Provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	80 Nos.	56 nos	MR
	• Types	ABC & CO ₂	ABC / CO ₂ /W.CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR

6.	First Aid Hose Reels.			
	• Total numbers on each floor	Required	BF=01No.GF=10Nos. & FF=07Nos.	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	Provided in basement	MR
	• Location of Repeater Panel	Required	Provided at reception	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement.	Required	Provided	MR
	• Ground & Above floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	150mm	150mm	MR
	• Number of Hydrant per floor	Required	BF=01No.GF=10Nos. & FF=07Nos.	MR
	• Hose box.	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	04 Nos.	MR
	• Hose box	Required	04 Nos.	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	1830 LPM	1830 LPM	MR
	➤ Head of main pump.	70 m	70 m	MR
	➤ Number of main pumps.	02Nos.	02Nos.	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	70 m	70 m	MR
	➤ Standby Pump output.	1830 LPM	1830 LPM	MR
	➤ Standby Pump head.	70 m	70 m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	90,000 Ltrs	90,000 Ltrs	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltrs	10,000 Ltrs	MR

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector System Panel.	Required	Provided	MR
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	CO ₂ & ABC Fire Extinguishers provided in electric panel room	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/Club/SZ/2017/1373 dated 18/09/2017, renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

DFA is put up for approval & signature please.

[Handwritten Signature]
12/10

Signature of the Inspecting Officer
Name : S.K. Dua
Designation: DO (SD)

DCFO(S2) → NOT posted *[Handwritten]* 27/10

[Handwritten Signature]
cfo

[Handwritten Signature]
28/10

[Handwritten Signature]

DUG | IS posted for *[Handwritten]*
2/11/20



[Handwritten Signature]
Dd/son

P.T.O