GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/Indl./SZ/2020/ 483 Dated: 09/11 /2020

FIRE SAFETY CERTIFICATE

Certified that **Building at Plot No. S-69, FIEE, Okhla Phase-II, New Delhi-110020**, comprised of Two Basements, Stilt, Ground + Two upper floors was inspected by the officers concerned of this department along with team of officers from SDMC on 29/10/2020 in the presence of Mr. Abhishek Mishra (Manager) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the said building / premises is fit for occupancy class **" Industrial" Group-G** with effect from 09/11/ /2020 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09 / 11 /2020 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. Authorized Signatory, Building at Plot No. S-69, FIEE, Okhla Phase-II, New Delhi-110020.
2. The Executive Engineer (Bldg.) HQ, SDMC, 9th Floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the Validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	Building at Plot No. S-69, FIEE, Okhla Phase-II, New Delhi-110020.		
2	Type of Occupancy	Group–G (Industrial)		
3	Building Comprised of	2 Basement + Stilt+ Ground floor + 2 upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2020/BP/101 dated 04/03/2020		
7	Date of Inspection	Joint Inspection with SDMC on 29/10/2020		
8	Name of the Inspecting Officers	DO S.K. Dua & ADO Avtar Singh		
9	Name & Designation of Officers from the building side	AE (SDMC) Deepak Kapila & Mr. Abhishek Mishra (Manager)		
10	Year of construction	2020		
11	Applicant letter No.	Online ID No. 10078987 dated 27/10/2020		
S. No.	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**NBC/UBBL Requirement**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to Building.**			
	➢ Road width	9m	13m	MR
	➢ Gate width	4.5m	5m	MR
	➢ Width of internal road	-N/A-	-N/A-	-N/A-
2	**Number, width, type & arrangement of exits.**			
	a) Number of Staircase			
	➢ Upper floors.	2 Nos	Provided	MR
	➢ Basement floor.	2 Nos	Provided	MR
	b) Width of Staircase			
	➢ Upper floors	1.50 m	1.50 m (each)	MR
	➢ Basement floor	1.50 m	1.50 m (each)	MR
	c) Protection of exits			
	➢ Fire check door	Required	Provided	MR
	➢ Pressurization	Required	Provided	MR
	d)No. of continuous staircase to terrace	02 Nos	02 Nos	MR
	e)Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.5m	Provided	MR
3	**Compartmentation.**			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	**Smoke Management system.**			
	• Basement	30 ACPH	Exhaust Fan Provided	MR
	• Upper floors	12 ACPH	Exhaust Fan Provided	MR
5.	**Fire Extinguishers.**			
	• Total numbers	12 nos.	15 nos	MR
	• Types	ABC /CO_2	ABC & CO_2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	**First Aid Hose Reels.**			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	**Automatic fire detection & alarming system.**			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	**MOEFA**	-N/A-	Provided	-N/A-
9.	**Public Address System**	-N/A-	Provided	-N/A-
10.	**Automatic Sprinkler System**			
	• Basement.	Required	Provided	MR
	• Ground & Above floors	Required	Provided	MR
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	**Internal Hydrants.**			
	• Size of Riser / Down-comer	-N/A-	Provided	-N/A-
	• Number of Hydrant per floor	-N/A-	Provided	-N/A-
	• Hose box.	-N/A-	Provided	-N/A-
12.	**Yard Hydrants**			
	• Total number of hydrants	-N/A-	-N/A-	-N/A-
	• Hose box	-N/A-	-N/A-	-N/A-
13.	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➢ Head of main pump.	-N/A-	-N/A-	-N/A-
	➢ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➢ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➢ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➢ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➢ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➢ Auto Starting/Manual Stopping.	-N/A-	-N/A-	-N/A-
	➢ Pump house access	-N/A-	-N/A-	-N/A-
	• **Terrace Level**			
	➢ Discharge of pump.	900 LPM	900 LPM	MR
	➢ Head of pump.	40m	40m	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14.	**Captive water storage for firefighting.**			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➢ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➢ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➢ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	20,000 Ltrs.	20,000 Ltrs	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of lift shaft.	Required	Provided	MR
	• Pressurization of lift lobby.	Required	Provided	MR
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	**Standby Power Supply**	Required	Provided	MR
18.	**Refuge Area**			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A

19.	**Fire Control Room.**			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	**Special Fire Protection System for the Protection of special Risk, if any.**	-N/A-	-N/A-	-N/A-

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

02/11

Signature of the Inspecting Officer
Name: S. K. Dua
Designation: DO (SD)

02/11/2020

Signature of the Inspecting Officer
Name: Avtar Singh
Designation: ADO (MR)

DCFO (SZ)

3/11

C. F. O.

DELHI FIRE SERVICE
Date 04/11
Diary No. 1078
Chief Fire Officer

04/11

D/S Spk

DCFO/N/SZ

F.t. letter is put up for signature please.

Director
9/11/20