

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2020 / 458

Dated: 3 / 11 / 2020

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary School** located at **Tigipur, Delhi-110036** comprised of **Single blocks- Ground+ 01 upper floor** owned/ occupied by **M.C. Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2017/School/WZ/330 dated 08.03.2017**. The premises was re-inspected by the officer concerned of this department on **04.09.2020** in presence of **Sh. Gaje Singh, Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from**3/11/2020** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **3/11/2020**..... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi – 54
2. The Principal, M.C. Primary School, Tigipur, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

21/10

INSPECTION REPORT

1. Name & address of the building : : M.C Primary School, Tigipur, Delhi-110036.
2. Type of Occupancy : : Educational
3. Type of Case : : Renewal Single blocks (G+3 upper floors)
4. Details of previous NOC : : F.6/DFS/MS/2017/School/WZ 330 Dated: 08.03.2017
5. Fire Safety directives letter No : : Director of Education Circular dated 01.03.2011
6. Date of inspection : : 20.10.2020
7. Name of the Inspecting Officers : : ADO (RN)
8. Name and designation of officers from the building side : : Sh. Gaje Singh (Principal)
9. Year of Construction : : 2013
10. Applicant's letter No. : : Online E-mail I.D Dated- 29.09.2020

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.5m	1.5m & 1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	NA	NA	NA	
3	Compartmentation.	1 m	1.12m double door	MR
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

A

	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	05nos	06nos	MR
		ABC Co2	ABC - GG	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA

	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	N/A	N/A
	➤ Head of Main pump	NA	N/A	N/A
	➤ Number of main pumps	NA	N/A	N/A
	➤ Jockey Pump out put	NA	N/A	N/A
	➤ Jockey pump head	NA	N/A	N/A
	➤ Standby Pump out put	NA	N/A	N/A
	➤ Standby Pump Head	NA	N/A	N/A
	➤ Auto Starting/ Manual stopping	NA	N/A	N/A
	➤ Pump House Access	NA	N/A	N/A
	• Terrace level	NA	N/A	N/A
	➤ Discharge of pump			
	➤ Head of the pump	NA	N/A	NA
	➤ Power Supply	NA	N/A	NA
	➤ Auto Starting of pump	NA	N/A	N/A
		NA	N/A	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	N/A	NA
15	Exit Signage.			
		NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	N/A	N/A
	• Pressurization of Lift lobby	NA	N/A	N/A
	• Communication In lift Car	NA	N/A	N/A
	• Fireman's Grounding Switch	NA	N/A	N/A
	• Lift Signage	NA	N/A	N/A
17	Standby power supply			
		NA	N/A	N/A
18	Refuge Area.			
	➤ Total Area	NA	N/A	N/A
	➤ Location	NA	N/A	N/A

k

19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.509 dated 05/04/2017.

[Signature]
28/10/2017

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN

[Signature]
Dy Cfo/W2

[Signature]
29/10/2017

[Signature]
A.D.O/R.N

As approved, F.S. certificate is put up for your signature P1

[Signature]
30/10/2017

[Signature]
Dy Cfo/W2

[Signature]
2/11/2017

[Signature]
NSP/CEP