

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2020/NDZ/ 463

Dated: 4/11/2020

FIRE SAFETY CERTIFICATE

Certified that the Nutan Vidya Mandir Sr. Sec. School located at G.T.B. Enclave, Dilshad Garden, Delhi-10093, comprised of ground plus three upper floors, owned/occupied by Nutan Vidya Mandir Sr. Sec. School, was issued FSC vide letter No. F6/MS/DFS/School/2017/NDZ/1494 dated 16/10/17. The school building was inspected by the officer concerned of this department in the presence of Mr. Kumar, Superintendent of the school and found that the school have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building fit for occupancy class "B" 'Educational Building' with effect from ~~...~~ 4/11/2020 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on ~~...~~ 4/11/2020 at New Delhi by.


(Sunil Chawdhary)
Dy. Chief Fire Officer

To,
The Manager,
Nutan Vidya Mandir Sr. Sec. School
G.T.B. Enclave, Dilshad Garden,
Delhi-10093

Copy:-
The Dy. Director of Education,
B- Block, Yamuna Vihar,
Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

M11

1. Name & address of the building : Nutan Vidya Mandir Sr. Sec. School
G.T.B. Enclave, Dilshad Garden, Delhi-10093
2. Building is comprised of : Ground plus three upper floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2017/NDZ/1494 dt 16/10/17
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 23/10/2020
8. Name of the Inspecting officers : DO F. Brown
9. Name and designation of Officer
from the building side : Mr.. Kumar (Superintendent)
10. Year of Construction : 1992
11. Applicant's letter No : Nil, dated 09/10/2020

| Sr. No. | Minimum Standards on fire prevention and fire safety U/R33 | NBC Part IV Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|-------------------------|----------------------|----------------|
| 01 | Access to building. | | | |
| | • Road width | 06 mtr. | 12 mtr. | MR |
| | • Gate width | 06 mtr. | 06 mtr. | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor | 01 no | 02 no. | MR |
| | • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | • Upper Floor | 1.50 mtr | 1.65 mtr. each | MR |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | 01 no. | 02 no. | MR |
| | e. Width of Corridor | 1.50 mtr. | 02 mtr | MR |
| | f. Door Size class room | 01 mtr. | 01 mtr. | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 05. | Fire Extinguishers. | | | |
| | • Total numbers | 14 nos. | 14 nos. | MR |
| | • types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

nd
on
ew

10.

| | | | | |
|----|---|-------------|------------|-----|
| 06 | First-aid-Hose Reels. | | | |
| | Total numbers on each floor | 01 no. | 01 no. | MR |
| | • Length of hose reel hose | 30 mtr | 30 mtr | MR |
| | • Nozzle diameter | 05 mm | 05 mm | MR |
| 07 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 08 | MOEFA | N/A | Provided | MR |
| 09 | Public address System. | N/A | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | Provided | MR |
| | • Number of hydrants per floor | N/A | 01 nos. | MR |
| | • Hose Box | N/A | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | 450 Lpm. | 450 Lpm. | MR |
| | ➤ Head of the Pump | 40 mtr | 40 mtr | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | Required | N/A | N/A |
| | • Overhead Tank capacity | 10,000 Ltr. | Provided | MR |
| 15 | Exit Signage. | Required | 10,000 Ltr | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |

N/13

| | | | | |
|----|--|-----|----------|-----|
| 17 | Standby power supply | N/A | Provided | MR |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial deemed compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to renew Fire Safety Certificate.

[Signature]
23/10

Signature of the Inspecting Officer
Name : F. Brown
Designation : DO (ED)

Dy. CFO (NDZ)

[Signature]
24/11

F.t. letter is prepared and put up for circulation pls.

Dy. CFO (NDZ)

[Signature]
27/10

[Signature]
26/10