

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2020 / 502

Dated: 12 / 11 / 2020

FIRE SAFETY CERTIFICATE

Certified that the **Rama Public School** located at **Kh.no-118, Jagat Pur Road, Wazirabad Extn, Delhi-110086** comprised of **Ground and 02 upper floors** owned/ occupied by the **Rama Public School** was issued Fire Safety Certificate vide this office letter no. **F.6/DFS/MS/2019/2330** dated **17.12.2019**, for **Ground and 01 floor only**. The premises was re-inspected by the officer concerned of this department on **30.10.2020** in presence of **Sh. Pankaj Choudhary, Manager** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Education "Group B** with effect from **..12.11.2020..** for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the condition under

Issued on.....12/11/2020.....at New Delhi by



(Atul Garg)

Director

Ph.-011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, Rama Public School, Kh.No-118 ,Jagat Pur Road, Wazirabad Extn.Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/S

INSPECTION REPORT

1. Name & address of the building : Rama Public School, Kh. No-118, Jagat Pur Road, Wazirabad Extn, Delhi-86.
2. Type of Occupancy : Educational
3. Type of Case : Add. /Alt. (G+02 upper floor)
4. Details of previous NOC : F6/DFS/MS/2019/2330 Dated: 17.12.2019 (Ground+01)
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/ NBC Part-4
6. Date of inspection : 30/10/2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Pankaj Singh (Manager)
9. Year of Construction : 2000/2019
10. Applicant's letter No. : Email ID Dated- 23.10.2020

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-4	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06m	06m	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	G & 1 st floor 1m II floor- 1.20m	1.0 m & 1.20m (2 nd floor)	MR
	3	Compartmentation.		

2/16

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	08nos	10nos	MR
		ABC/CO2	ABC-8/Co2-2	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA

Op

n/12

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 lpm	450 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000ltr	10,000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	N/A	N/A	N/A
		N/A	N/A	N/A

12

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, it is recommended to issue Fire Safety Certificate under sub Rule 3 of Rule 35 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer
 Name :- C. L. MEENA
 Designation:- ADO/RN



Handwritten notes:
 CDF
 Dy SFO (WZ)

Handwritten signature:

Handwritten notes:
 done
 6/11

Handwritten notes:
 done
 6/11/20

Handwritten notes:
 May RN

As approved, F.T. letter is put up for