FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/WZ/2020/ 163 **Dated:**24/11/**2020**

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Bengal Sweet Corner Located at Suman Tower, 36, Central Market, Phase-1, Ashok Vihar-110052 on Ground Floor&Mez. Floor**in a building comprised of Basement+ Ground +Mez. Floor + 03 upper Floors owned /occupied by**M/s. Bengal Sweet Corner** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 28/09/2020 in the presence of **Sh. Ganesh Lal** that the premises is fit for occupancy class " **Assembly" Group D (Ground &Mez. Floor)**with effect from 24/11/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ....24/11/2020.. at New Delhi by.

(AtulGarg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. The Dy. Health Officer, Keshav Puram Zone,NDMC, Public Health Department, A-1 Block KeshavPuram Zone, Delhi.
3. M/s. Bengal Sweet Corner, Suman Tower, 36, Central Market, Phase-1, Ashok Vihar-110052

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/76

INSPECTION REPORT

1. Name & address of the building: **M/s. Bengal Sweet Corner Located at Suman Tower, 36, Central Market, Phase-1, Ashok Vihar-110052**
2. Type of Occupancy : **Assembly at Ground Floor & Maz. Floor** in a building comprise of B+G+3Upper Floors
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. :Nil
6. Date of inspection : 28/09/2020
7. Name of the Inspecting Officer :Sh. Udai Vir Singh ADO (WP)
8. Name and designation of Officer

   from the building side : Sh. Ganesh Lal
9. Year of Construction : Before 1982
10. Applicant's online letter No. : 2020091006803 dated-17/09/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular dated 11/11/05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	In DDA Market	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	2 x120cm	120cm(internal) 120cm(common with complex) & 77cm	MR
	• Basements	2 Exits	115cm &67 cm	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 Exits	GF=156cm,117cm,107cm,92cm,98cm Maz, F=110cm ,Open to stair & 82cm	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust Fan Provided	MR
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	04nos. each type	Provided	MR
	• Types	DCP, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided (wall mounted)	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	Provided	MR
	• Number of hydrants per floor	NA	Provided	MR
	• Hose Box	NA	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Staring/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	450 lpm	Provided	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR

14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➢ Draw off connection	NA	NA	NA
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5, 000 litres	provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	NA	NA	NA
	➢ Fireman's Grounding Switch	NA	NA	NA
	➢ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➢ Total area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire control room			
	➢ Detector system panel	NA	NA	NA
	➢ Flow Switch Panel	NA	NA	NA
	➢ PA System Panel	NA	NA	NA
	➢ Battery backup	NA	NA	NA
	➢ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....Nil.....

1. **The Bengal Sweet Corner, Located at, Suman Tower, 36, Central Market, Phase-1, Ashok Vihar-110052**
2. **The total covered area for restaurant = 191.47 M^2**
3. **As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 106 (191.47/1.8=106.37 say 106) for whole restaurant.**
4. **The total seating capacity comes out be 106.**

29/9

Signature of the Inspecting Officer
Name: Sh. Udai Vir Singh
Designation: ADO/WP

Signature of the Inspecting Officer
Name
Designation

DO/CO

29/9/2020

what about Nos 7 Stairs case