

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Indl./2020/SZ/ 500

Dated: 01/12/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s Carmann Auto Pvt. Ltd. located at A-33, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044, comprised of Basement, Ground and Two upper floors was granted NOC by this department vide letter No. F.6/DFS/MS/Industrial/SZ/2017/1833 dated 20/12/2017. The premises was re-inspected by officer concerned of this department on 21/11/2020 in the presence of Mr. Pritesh Singh (Safety Officer) & Satyam Singh (Facility Manager) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules-2010 and that premises/building is fit for occupancy **Group G "Industrial"**, effect from 01/12/2020... for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 01/12/2020 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. M/s Carmann Auto Pvt. Ltd. located at A-33, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044
2. The executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M/s Carmann Auto Pvt. Ltd., A-33, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044		
2	Type of Occupancy	Group-G (Industrial)		
3	Building Comprised of	Basement + Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Industrial/SZ/2017/1833 dated 20/12/2017		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2008/1289 dated 05/05/2008		
7	Date of Inspection	21/11/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Pritesh Singh (Safety Officer) & Satyam Singh (Facility Manager)		
10	Year of construction	2007-08		
11	Applicant letter No.	Email dated 17/11/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	9 m	Provided ✓	MR
	➤ Gate width	5 m	2 nos of 5m ✓	MR
	➤ Width of internal road	-NA-	Provided	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Three	Provided ✓	MR
	➤ Basement floor.	Three	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.25 m	1.5 m each ✓	MR
	➤ Basement floor	1.25 m	1.5 m each ✓	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA- ✓	-NA-
	d) No. of continuous staircase to terrace	Three	Provided	MR
	e) Width of corridor	NA-	NA-	NA-
	f) Door size	1 m	1 m (final exit) ✓	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	M. V. Provided	MR
	• Upper floors	12 ACPH	M. V. Provided	MR
5	Fire Extinguishers.			
	• Total numbers	20 Nos	26 Nos ✓	MR
	• Types	ABC /CO ₂ /W.CO ₂	10/06/10 Nos ✓	MR
	• ISI Marking	ISI marked	Yes	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor	Three	Provided ✓	MR
	• Length of hose-reel hose.	30 m	Provided	MR

	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & Heat	Provided	MR
		Ground floor	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Every floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Ground & Above floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		Three	Provided	MR
		Three	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	Required	4 Nos	MR
		Required	4 Nos	MR
13.	Pumping arrangements.			
	• Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access 	2280 LPM	Provided	MR
		60 m	Provided	MR
		One	Provided	MR
		180 LPM	Provided	MR
		60 m	Provided	MR
		2280 LPM	Provided	MR
		60 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		• Terrace Level		
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. 	1,00,000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	• Overhead tank capacity.	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required Manual CO ₂ System	02 ABC type fire extinguisher found provided	MR(Old Case)

The fire protection system provided in the building was test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on the prevention and fire safety measures as required under the rules, the NOC issued vide letter no. F/6/DFS/MS/Industrial/SZ/2017/1833 dated 20/12/2017 renewal under rule 37 of the Delhi Fire Service rule 2010 is recommended

Accordingly DFA is put up for approval and signature please.

(Signature)
24/11/2020

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.RD)

DO (SD)

(Signature)
25/11

(Signature)
25/11

F. T. please

(Signature)
25/11

ADO (M.RD)

RT letter is put up for sign please
(Signature)