

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2020/519

Dated: 27/11/2020

FIRE SAFETY CERTIFICATE

Certified that the : Govt. Boys Sr. Sec. School, located at Goela Khurd, New Delhi 110071 comprised of total 07 blocks 03 block Ground Floor only and 04 block Ground+01 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2017/SZ/367 Dated 14/07/2017 The premises was re inspected by the officer concerned of this department on 17/11/2020 in the presence of Mr. Dharamveer Singh (HOO) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 27/11/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/11/2020 at New Delhi by.


Sunil Choudhary
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The : Govt. Boys Sr. Sec. School, **located at** Goela Khurd, New Delhi 110071. School ID-1822257
2. Directorate of Education Old Secretariat Delhi – 110054

following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Govt. Boys Sr. Sec. School, **located at** Goela Khurd, New Delhi 110071(School ID-1822257)
2. Type of Occupancy : Educational total 07 blocks- 03 block Ground Floor only and 04 block Ground+01 Upper Floors Only
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/School/2017/SZ/367 Dated 14/07/2017
5. Fire Safety directives Letter No. : DOE 3298-3398 date01.03.2011
6. Date of inspection :17/11/2020
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Mr. Dharamveer Singh (HOO)
9. Year of Construction : 2011
10. Applicant's letter No. :GBSS/GK/2020-21 Dated 24/07/2020

No. of Students=1740
 No. of class rooms=41
 Plot area=22105Sq.m²
 Covered area=2999.75sqm²

S N o	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible 06 mtrs 4.5mtrs NA 	<ul style="list-style-type: none"> 10mtrs Accessible (old case) NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 01 No in Blk-05,06,7&08 NA 150cm NA NA NA NA NA 150cms 1 mtr 	<ul style="list-style-type: none"> Provided NA BL-07=140cm,BL-5=150cmBL-06=150cm& BL-08=160cm NA NA NA NA 170 cms 100 cm (double door) including door frame 	<ul style="list-style-type: none"> MR NA MR(old case) NA NA NA NA MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity			NA
15	Exit Signage	NA	NA	
16.	Provision of Lifts			NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	
18.	Refuge Area			NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2017/SZ/367 Dated 14/07/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- One block comprising ground floor only has been demolished.

Signature of the Inspecting Officer

Name

Uday Vir Singh
ADG/DWR

F.T. please

Uday Vir Singh

A No. [Signature]