

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F.6/DFS/MS/SZ/2020 / 167

Dated 27/11/2020

FIRE SAFETY CERTIFICATE

Certified that M/s Haldiram Products Pvt. Ltd, Located at 4B/16,GF,FF&SF, Najafgarh Road, Tilak Nagar, New Delhi-110018 in a building comprised of B,G & 2 UF was issued FSC vide Letter No. F6/DFS/MS/2018/EH/SZ/421 dated 15-03-2018. The premises was re inspected by the officers concerned of this department on 19-11-2020 in the presence of Mr. Sunil Kumar) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D (At ground, 1st & 2nd Floors only) with effect from 27/11/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/11/2020..... at New Delhi by.

Sunil Choudhary
Dy Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. M/s Haldiram Products Pvt. Ltd, Located at 4B/16, Najafgarh Road, Tilak Nagar, New Delhi-

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Haldiram Products Pvt. Ltd, Located at
4B/16, Najafgarh Road, Tilak Nagar, New Delhi-110018
2. Type of Occupancy : Group D – Assembly (Building) The building comprised
of Basement+G+2 Upper Floor & Restaurant Running at Ground & 2upper
Floors only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/EH/SZ/421 dated 15-03-
2018
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 19-11-2020
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
a. from the building side : Mr. Sunil Kumar (Shift Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : 2020102708069 dated 28/102020

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per Noting N/12 -14.	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible(09mtrs)	12mtrs	MR
	• Gate width	06mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	02	MR
	• Basements	NA	1	NA, restaurant running at GF, FF&SF
	b. Width of staircases			
	• Upper floors	1.5 & 1 mtrs	153 & 104 cms	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width Of Corridor	1.5mtr	Opening in hall	MR
	f. Door Size	02mtrs & 1m	Provided	MR (old case)

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required	Provided	MR
		Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	03no's/floor ABC & CO ₂	Provided	MR
			Provided	MR
		ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke& Heat	Provided	MR
		Required	Basement	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Near exit	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	100mm	Provided	MR
		01No's	Provided	MR
		01No's	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900lpm	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	MR
		10000ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA


20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2018/EH/421 dated 15/03/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ASO/DWR

Signature of the Inspecting Officer
 Name F. F. Puri
 Designation

Dy. Insp. 2 

A.O. (J. A.)

hir letter is put up for sign ple

Dy. Insp. 2  26/11

MS. 