

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2020/SZ/166

Dated: 27/11/2020

FIRE SAFETY CERTIFICATE

Certified that M/s **KLAP** (A unit of Smangs Hospitality LLP) located at Flat No. 2 & 3, First & Second Floor, Khan Market, New Delhi-110003, comprised of **ground plus two upper floors** was issued FSC by this department in the name & style "**The Last Call**" vide letter No. F.6/DFS/MS/EH/SZ/2017/1575 dated 03/11/2017. The premise was re-inspected by the officer concerned of this department on 11/11/2020 in the presence of Mr. Rajesh Kashyap and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D "**Assembly Building**" (Restaurant) as above with effect from 27/11/2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/11/2020 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Joint Comm. of Police. (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
2. The DHO (SZ), South MCD, Health Department, Green Park, New Delhi-110016
3. Mr. Navdeep Singh Sethi M/s KLAP (A unit of Smangs Hospitality LLP), Flat No. 2 & 3, First & Second Floor, Khan Market, New Delhi-110003

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s K LAP (A unit of Smangs Hospitality LLP), Flat No. 2 & 3, First & Second Floor, Khan Market, New Delhi-110003		
2	Type of Occupancy	Assembly "Group-D" (Restaurant)		
3	Building Comprised of	Ground plus two upper floors.		
4	Type of Case	Name Change / Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/SZ/2017/1575 dated 03/11/2017 in the name & style of "The Last Call"		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	11/11/2020		
8	Name of the Inspecting Officers	S.K. Dua, DO (SD) & A.K. Jaiswal, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Rajesh Kashyap		
10	Year of construction	2008-09		
11	Applicant letter No.	Online No. 2020101707805 dated 17/10/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	6m	MR
		N/A	Directly accessible from main road	N/A
		N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	2 Nos	2 Nos	MR
		N/A	N/A	N/A
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	1.0m each	1.0m each	MR (old case)
		N/A	N/A	N/A
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01 No	01 No	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1m	1m (Final exit)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH	N/A	N/A
		12 ACPH	Exhaust Fans Provided	MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Required	6 Nos	MR
		ABC / CO ₂	ABC & CO ₂	MR
		Required	Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	01 No.	01 No.	MR
		30m	30m	MR
		5mm	5mm	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	Smoke type	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	Provided	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floor 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	1 No	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	1 No	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 & 180 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	Required	40m	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	One CO2 type fire extinguisher provided near electrical panel	N/A

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/EH/SZ/2017/1575 dated 03/11/2017 in the name & style of "The Last Call", renewal under Rule 37 of the Delhi Fire Service Rules 2010, is recommended in the name & style "KLAP" (A unit of Smangs Hospitality LLP).

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
 Name: S.K. Dua
 Designation: DO (SD)

DCFO (SZ)

Signature of the Inspecting Officer
 Name: A.K. Jaiswal
 Designation: ADO (SJ)

[Handwritten Signature]
 28/11

[Handwritten Signature]
 20/11/2020

F.T. please

[Handwritten Signature]
 28/11
 ADO/Jwp

*Sir,
 F.T. is added for sign. pl.*

Dy CFO (SZ)

[Handwritten Signature]
 28/11/2020

[Handwritten Signature]
 28/11

M.S. cell