

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No.F6/DFS/MS/School/2020/SZ/533

Dated: 04/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Adarsh Kindergarten, C-Block, vikaspuri, New delhi-110018, comprised of ground plus Two upper floor, having total 24 rooms (including Class Rooms, Office comp. Room, & Store etc) owned/occupied by B.R..Memorial society(Regd.) was issued FSC by this Department vide letter F.6/DFS/MS/School/2017/SZ/341 dated 08/03/2017. The School building was re-inspected by the officer concerned of this department on 25/11/2020 in the presence of Mr. Prashant Sehgal (Admin. Officer) and found that the Adarsh Kindergarten have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and found that the building/ premises is fit for occupancy class 'Educational' for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....04/12/2020.....at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Chairman,
Adarsh Kindergarten
C-Block, vikaspuri, New delhi-110018
- 2 Director of Education,
Govt. of NCT of Delhi, old Secretariat,
New Delhi-110054.

Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

- N/8
1. Name & address of the building : Adarsh Kindergarten, C-Block, vikaspuri, New Delhi-110018.
 2. Building is comprised of : G+2floors
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F.6/DFS/MS/School/2017/SZ/341 dated 08/03/17
 6. Fire Safety Circular No. : Nil
 7. Date of Inspection : 25/11/2020
 8. Name of the Inspecting officers : ADO R.K. Yadav
 9. Name and designation of Officer from the building side : Smt. Prashant sahal (admin. Officer)
 10. Year of Construction : 2001-2002
 11. Applicant's letter No : Dated 09/11/2020

No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per FSC dt. 15.10.2013	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Old Case	05 m	MR, being old case
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	150 cms/additional staircase of 75 cms if less than 150 cms	145 & 75 cms	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	two	N/A
	g. Width of Corridor	150 cms	150 cms	MR
	h. Door Size	100 cms	110 cms	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	Provided	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no. per floor	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	one	N/A
	• Hose Box	N/A	one	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM & 180 LPM Provided	MR
	➤ Head of the Pump	40 mtrs	N/A	MR
	➤ Power supply	Required	N/A	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	10,000 ltrs	N/A	MR
	• Overhead Tank capacity	Required	Provided	MR

		Required	Provided	MR
15	Exit Sinage			
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under the circular no. F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11.

R. K. Yadav
20/11/2020

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO(Janakpuri)

DYCFO
[Signature]

F.T. Prasad

F.T. Prasad as per copy for sign for
~~*[Signature]*~~

ADO (F.T.)

mseell