

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2020/NDZ/ 501

Dated: 01/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Bimla Devi Hospital located at, Plot No.5, Pkt-B, Mayur Vihar Ph-II, Delhi-91, Comprised of basement ground plus two upper floors owned/occupied by Dr. Walia Charitable Trust was issued Fire Safety Certificate vide letter No. F6/MS/DFS/Hospital/2002/790 dated 14/05/2002. The Hospital building was re-inspected by the team of officers of this department in the presence of Manager and found that the institutional building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules, 2010 and found that the hospital building is fit for occupancy class "C" 'Institutional Building' for basement, ground plus two upper floors with effect from 01/12/2020 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 01/12/2020 at New Delhi by

S.K. Tomar
11/12/2020

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

[Signature]

To,
The Director,
Bimla Devi Hospital located at, Plot No.5, Pkt-B,
Mayur Vihar Ph-II, Delhi-110091

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Bimla Devi Hospital.
Plot No.5, Pkt-B, Mayur Vihar Ph-II, Delhi-91.
2. Building is comprised of : Basement, Ground plus two upper floors
3. Type of Occupancy : Institutional building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/MS/DFS/Hospital/2002/790 dated 14/05/2002
6. Fire Safety directive letter No. : F6/ DFS/MS/98/BP/Hospital/1704 dt 01/09/1998
7. Date of Inspection : 20/11/2020
8. Name of the Inspecting officers : DO F. Brown & ADO M. K. Sharma
9. Name and designation of Officer from the building side : Manager
10. Year of Construction : 1997,
11. Applicant's letter No : Nil dated 12/11/2020

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	15 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper floor	02 mtr & 1.50 mtr	02 mtr & 1.75 mtr	MR
	• Basement	02 mtr & 1.50 mtr	02 mtr & 1.75 mtr	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr	02 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided (Natural Vetilated)	MR
05.	Fire Extinguishers			
	• Total numbers	15 nos.	18 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

Mur

06	First-Aid-Hose Reels.			
	Total numbers on each Branch	01 no	01 no	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Required	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	• Head of main pump	70 mtrs	70 mtrs	MR
	• Number of main pumps	01 nos.	01 nos.	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	70 mtrs	70 mtrs	MR
	• Standby pump out put	1620 lpm	1620 lpm	MR
	• Standby pump head	70 mtrs.	70 mtrs.	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	900 lpm	900 lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 ltr	50,000 ltr	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	rovided	MR
	• Overhead tank capacity	25,000 ltr	25,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

MW

N/17

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The Shortcomings conveyed vide F6/DFS/MS/Hospital/2019/7574 on dated 19/12/1998 has been complied.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew Fire Safety Certificate.

[Handwritten Signature]
28/11

Signature of the Inspecting Officer
Name :- F. Brown
Designation :- D.O (ED)

[Handwritten Signature]
28/11/20

Signature of the Inspecting Officer
Name :- M.K. Sharma
Designation :- A.D.O (LN)

DY. CRO (LN)

F. G. pl, Spk.

[Handwritten Signature]
25/11/2020

ADOC (LN)

F.T. letter is put up for sign

D.C. (LN)

[Handwritten Signature]
11/12/2020

[Handwritten Signature]
28/11