

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2020/ 52/School/526

Dated: 02/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed Sr. Sec. School, located at Kazipur, New Delhi 110073 comprised of total 02 blocks (Old block & New Block) Each block is having ground plus one upper floor was issued FSC vide Letter No F6/DFS/MS/School/2017/SZ/1553 Dated 31/10/2017 The premises was re inspected by the officer concerned of this department on 17/11/2020 in the presence of Mr. Ram Chandra Rodiwal (V. Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298 – 3398 Dated 01/03/2011 and that the premises is fit for occupancy class “Educational” Group B with effect from 02/12/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/12/2020 at New Delhi by.


(Sunil Choudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal,
Govt.Co-ed Sr. Sec. School, located at Kazipur, New Delhi 110073
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Govt. Co-ed Sr. Sec. School, **located at Kazipur, New Delhi-110073**
2. Type of Occupancy : Educational total 02 blocks Ground+01 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/School/2017/SZ/1553 Dated 31/10/2017
5. Fire Safety directives Letter No. : DOE 3298-3398 date01.03.2011
6. Date of inspection :17/11/2020
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Mr. Ram Chandra Rodiwal (V. Principal)
9. Year of Construction : Old 1994 New 2005
10. Applicant's letter No. :GBSS/GK/2020-21 Dated 24/07/2020

No. of Students=122
No. of class rooms=27
Plot area=15226Sq.m ²
Covered area=1700sqm ²

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 date01.03.2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5mtrs NA	Provided Directly accessible from road NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	02 no's in each block NA	02 no's in each block NA NA	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	150cm additional staircase of 75 cm if less than 150 cm NA	137&137cms in O blk &155 &155 cms in N blk NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • Upper floors 	150cms 100 cm	152 cms 1m (including door frame) in each blk	MR MR, being old case
	f. Door Size			

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural Ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	16 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR
5.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements.	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump 	NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
15	Exit Signage	NA	NA	NA	NA
16.	Provision of Lifts				
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
17.	Standby power supply	NA	NA	NA	NA
18.	Refuge Area				
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA	NA
		NA	NA	NA	NA
19.	Fire control room				
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2017/SZ/1553 Dated 31/10/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 AD(DWR)

Dyefo/s2

F.T. pl.
~~25/11~~
 AD(PUR)

Sir RT letter is put up for sign

~~25/11~~

Dyefo/s2

~~27/11~~

M.S. Ull