

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO F 6/DFS/MS/ Institute /2020/ 503

Dated 01/12/20

FIRE SAFETY CERTIFICATE

Certified that the building of Management Education and Research Institute, 53-54, Institutional area, Janakpuri, New Delhi -58, comprised of **Basements, Ground +7 Upper Floors**, owned/ occupied by MERI, The Institute was inspected by the officers concerned of this department on 23.11.2020 in the presence of Shri Lalit Aggrawal (Director). and found that Institute have Complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010 and that the building/premises is fit for occupancy class **Educational Building** with effect from 01/12/20 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire service rule 2010. Printed as below.

Issued on 01/12/20 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to :-

- 1..The Authorized signatory, Management Education and Research Institute, 53-54, Institutional area, Janakpuri, New Delhi -58.
- 2.The Vce Chancellor, I.P University, sector -16 C, Dwarka New Delhi-78

Following fire safety directives may be adhered to :-

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per NBC / BBL 1983.
6. This NOC may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The access around the blocks as submitted in the plans submitted by Principal Architect Design Plus shall be kept clear of any obstruction for free movement of fire units in case of emergency.
9. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'the [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.
issued on ----- 01/12/2020 ----- at New Delhi by

N/15

INSPECTION REPORT

1. Name & address of the building:- Management Education and Research Institute, 53-54 institutional area, Janakpuri New Delhi 58
2. Type of occupancy:- Educational
Gr. + 07 Upper floor
3. Type of case:- New (addition/alteration)
4. Details of previous FSC:- No- F6/DFS/MS/2016/SZ/369 Dated- 08/03/2016
5. Fire safety directives No.- F6/DFS/MS/BP/2017/76 dated 21/03/2017
6. Date of inspection:- 23/11/2020
7. Name of the inspecting officer:- Sh. Sunil Chawdhary DY.CFO & R.K. Yadav(ADO)
8. Name & designation of officer
From the building side:- Sh. Lalit Aggrawal (Owner)
9. Year of construction:- Befor 2010 & 2019
10. Applicant's letter No:- Office/DDA/Fire Safety/2020/011/8355
Dated 17/11/2020

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	12 mtr.	MR
	2) Gate width	4.5 mtr.	4.65 & 2.40 mtr.	MR
	3) Width of internal road	6 mtr.	6 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	1.5 Mtr	1.5 mtr. each	MR
	2. Basements	1.5 Mtr	1.5 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	01	01	M/R
	E. Width of corridor	1.5 mtr	1.5 mtr	M/R
	F. Door size	1 mtr.	1.05 to 1.15 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	sealed	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Provided	M/R
	2) Upper floors	Required	Provided	M/R
5.	Fire Extinguishers			
	1) Total numbers	04 Nos. per floor	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	ISI	Provided	MR

Rte

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	M/R
	2) Hose box	02	02	M/R
13.	Pumping Arrangement			
	1) Ground level	Required	Provided	MR
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	70 mtr	70 mtr	M/R
	c) Number of main pump	01	01	M/R
	d) Jockey pump out put	180 LPM	180 LPM	M/R
	e) Jockey pump head	40 mtr	40 mtr	N/A
	f) Stand by pump output	2280 LPM	2280 LPM	MR
	g) Stand by pump head	70 mtr	70 mtr	M/R
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	30 mtr	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	100,000 ltr	100,000 ltr	M/R
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	25,000 ltrs.	25,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift	Required	Provided	MR

N/197

	shaft			
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	Required	Provided	M/R
	Total area location	At 7th Floor	Provided	M/R
19.	Fire Control Room	Required	Provided	M/R
	a) Detector system panel	Required	Provided	M/R
	b) Flow switch panel	Required	Provided	M/R
	c) PA system panel	Required	Provided	M/R
	d) Battery backup	Required	Provided	M/R
	e) Building floor plan	Required	Provided	M/R
20.	Special Fire Protection System for Protection of special Risk, if any:			M/R

The fire protection systems provided in the Institutional building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

R.K. Yadav
27/11/20

Signature of the Inspecting Officer
Name :- R.K Yadav
Designation :- ADO (J.P)

Sunil Chawdhary
25/11

Signature of the Inspecting Officer
Name :- Sunil Chawdhary
Designation :- DY. C F O

C.F.O.
[Signature]
27/11

[Signature]
27/11/20
AT PLK



[Signature]
is for signature