

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2020/School/WZ/ 532

Dated: 02/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **Ryan International School, Sector-25, Ph-III, Rohini, Delhi-110085** comprised of **Basement + Ground and 03 upper floors** owned/ occupied by **Ryan International School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2017/School/WZ/756 Dated: 26.05.2017**. The premise was re-inspected by the officer concerned of this department on **10.11.2020** in the presence of **Smt. Mamta Nanda (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from 02.12.2020..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 02.12.2020..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250
ale

Copy to :-

- 1 The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
- 2 The Principal, Ryan International School, Sec-25, Ph-III Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Ryan International School, , Sec-25, Ph-III Rohini, Delhi-85
2. Type of Occupancy : Educational
3. Type of Case : Renewal , (B + G + 03 upper floors)
4. Details of previous NOC : F6/DFS/MS/2017/School/WZ/756 Dated: 26.05.2017
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 16.11.2020
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers
from the building side : Smt. Mamta Nanda
9. Year of Construction : 1998
10. Applicant's letter No. : Online mail dated 07.11.2020

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m	MR
	• Gate width	06m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	04	04	MR
	b. Width of staircases			
	• Upper Floors	1.50m	1.80 m	MR
	• Basements	1.50m	1.80m each	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1.05m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Natural ventilated	MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	20 nos	20 nos	MR
		ABC/Co2	ABC---20	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	04	Provided	MR
	Length of hose reel hose	30m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	Size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	2	2 nos	MR
	Hose Box	2	2 nos	MR
12	Yard Hydrants.			
	Total number of hydrants	03	03	MR
	Hose Box	03	03	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		1620lpm	Provided	MR
		40m	Provided	MR
		N/A	N/A	N/A
		900lpm	Provided	MR
		40m	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900lpm	Provided	MR
	40m	40m	MR	
	Required	Provided	MR	
	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			

	<ul style="list-style-type: none"> Underground tank capacity 	100000 ltr	100000 ltr.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10, 000 ltrs	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2017/School/WZ/756 Dated: 26.05.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



Signature of the Inspecting Officer

Name :- A.K.Sharma

Designation:- ADO/Rohini

Dy. CFO (WZ)

Handwritten notes:
 ADO Rohini - A.T
 AT letter is put up for final approval and signature

Handwritten notes:
 AT letter is put up for final approval and signature