

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6 DFS/MS/School/2020/SZ /504

Dated: 02/12/2020

FIRE SAFETY CERTIFICATE

Certified that **Saiyid Hamid Academy** (A Unit of Indian Education Foundation), located at E-73, Lane no 6, Shaheen Bagh, Jamia Nagar, New Delhi-110025 comprised of Basement, Ground plus four upper floors was inspected by the officer concerned of this department on 02/11/2020 in presence of Mrs. Amita Mohan (Principal) of the school and found that said school building have complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service, 2010 and that the school building is fit for occupancy class "**Education Building**" **Group-B**, as above with effect from 02-12-2020 for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02-12-2020 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
ok A

Copy to: -

1. The Manager, Saiyid Hamid Academy located at E-73, Lane no 6, Shaheen Bagh, Jamia Nagar, New Delhi-110025
2. The Directorate of Education, Old Secretariat, GNCT of Delhi, New Delhi-110006

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Saiyid Hamid Academy (A Unit of Indian Education Foundation), located at E-73, Lane no 6, Shaheen Bagh, Jamia Nagar, New Delhi-110025		
2	Type of Occupancy	Group-B, "Educational Building"		
3	Building Comprised of	Basement, Ground plus four upper floors (Height of the building is less than 15 m as certified by Architect)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	02/11/2020		
8	Name of the Inspecting Officers	Avtar Singh ADO		
9	Name & Designation of Officers from the building side	Mrs. Amita Mohan (Principal)		
10	Year of construction	2015		
11	Applicant letter No.	Dairy No. 1205 dated 10/08/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements as Per NBC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	9 m	MR ✓
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 nos	02 nos	MR ✓
	➤ Basement floor	02 nos	02 nos	MR ✓
	b) Width of Staircase			
	➤ Upper floors	1.50 m & 1.25 m	1.60 m & 1.50 m	MR ✓
	➤ Basement floor	1.50 m & 1.25 m	1.50 m & 1.30 m	MR ✓
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	02 nos	02 nos	MR ✓
	e) Width of corridor	-N/A-	1.50 m	-N/A-
	f) Door size	1 m	1.10 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
4	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH	Exhaust fan	MR ✓
		12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	12 nos	12 No's	MR ✓
			ABC type	MR
		Required	Provided	MR ✓

6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA	-N/A-	-N/A-	-N/A-
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	• Basement.	Required	Provided	MR
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 m	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	15,000 ltrs	15,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	One ABC type fire extinguisher provided near electric panel ✓	MR

The fire protection system provided in the building was test checked and found functional at the time of inspection.

The shortcoming issued by this department vide letter No. F/6/DFS/MS/2016/2002 dated 19/08/2016 has been complied by the building management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

(Signature)
05/11/2020

Signature of the Inspecting Officer

Name : Avtar Singh

Designation: ADO (MR)

DO (SD)

P1. spec about letter dt. 05/11/18 placed at C/7.

(Signature)
05/11

ADO(MR)

This department has already issued shortcoming vide office letter No F-6/DFS/MS/2016/2002 dated 19/08/2016 placed at (C-4) for the same a composition of