

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020 / EH/w 2/173

Dated: 7/12/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s **Jubliant Foodworks Limited (Domino's Pizza Restaurant)** located at **GF, Property no. 29/4, Nagia Park, Shakti Nagar, Delhi-110009** in the building comprised of **B + G+ 03 upper floors** owned/ occupied by M/s **Jubliant Foodworks Limited Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **12.11.2020** in the presence of **Sh. Arjun, Manager** and that the building/ premise is fit for occupancy Class **Assembly** restaurant at **ground floor only** with effect from 7/12/2020 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7/12/2020.... at New Delhi by

(Atul Garg)
Director

Ph-011-23414000

Copy to:-

1. M/s Jubliant Foodworks Limited Restaurant, Shop No. 29/4, Nagia Park, Shakti Nagar, Delhi-110009.
2. The Dy. Health Officer, NDMC, Public Health Department City S.P.Zone, Old Hindu College, Kashmere Gate, Delhi.
3. Joint CP(Lic.) P.S. Defence Colony, New Delhi (Ref. Application no. 2020101707803).

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Jubliant Foodworks Limited Restaurant, Shop No. 29/4, GF, Nagai Park, Shakti Nagar, Delhi-110007.
2. Type of Occupancy : Assembly (Ground floor only) B+ G+03 upper floor
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 12.11.2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr. Arjun (Manager)
9. Year of Construction : 2000 (Residential) as per online application
10. Applicant's letter No. : Online I. D. no. 2020101707803 dated 03.11.2020

	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	12m approx...	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits (Restaurant at GF only)			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	1m	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2m & 1.50m	2.0m, 1.50m & 70cm	MR
	3	Compartmentation.		
• Fire check door		Required	Provided	MR
• Sealing of electrical shafts		NA	NA	NA

	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	12	30 l/c per hour	NA
		12	Required	NA
			Exhaust fans provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	05nos	06nos	MR
		ABC/Co2	ABC-5 Co2-1	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor(Ground floor) • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of pipe/down-comer • Number of hydrants per floor • Hose Box 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA

n/y

	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000 ltr	20,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ ^{issue} Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


23/11/2020

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation:- ADO/RN

~~DO (NW)~~

~~ADP~~
23/11/2020

~~Dy C.S. (W2)~~

~~[Signature]~~
24/11/2020

~~ADP~~

~~ADP~~
29/6

~~ADP~~
26/11/20

~~ADP NW~~
27/12/2020

Put up f.T. F.S.C.

~~ADO (RN)~~

